



**TETRA TECH EBA**

# **DEEP CREEK WATER SUPPLY WELL DC-2 WELL COMPLETION AND AQUIFER AND WELLHEAD PROTECTION REPORT**



PRESENTED TO  
**YUKON GOVERNMENT, COMMUNITY SERVICES, INFRASTRUCTURE  
DEVELOPMENT BRANCH**

MARCH 2014  
ISSUED FOR USE  
FILE: ENVH2O03020-01

---

This page intentionally left blank.

## EXECUTIVE SUMMARY

Tetra Tech EBA Inc. (Tetra Tech EBA) has been retained by Government of Yukon, Community Services, Infrastructure Development Branch (YG-IDB) to prepare a well completion report and an aquifer and wellhead protection plan (AWPP) for a proposed community water supply well (DC-2) to serve the planned Deep Creek Water Supply Facility located in Deep Creek, Yukon. This report has been prepared as per Government of Yukon Contract C00016678.

Well DC-2 was drilled from January 7 to 11, 2014 by Midnight Sun Drilling, Yukon, using an air rotary drill rig. A 203 mm (8") casing was advanced to 15.3 m into competent bedrock. A 152 mm (6") casing was then installed in the well and the annulus between the 152 mm and 203 mm casing was filled with bentonite chips to surface. The 152 mm casing was then advanced into competent bedrock at a final depth of 17.1 m bgs. DC-2 was completed at a depth of 122.5 m. The well was developed for seven hours by airlifting and surging.

The constant rate pumping test completed on the well indicates that it is completed within a fairly productive bedrock aquifer with a theoretical sustainable yield of 1.6 L/s. Tetra Tech EBA identified well DC-2 as non-GUDI based on a Phase 1 initial GUDI screening due to the well siting, construction and depth of the producing fractured bedrock aquifer, and the thickness of overlying competent bedrock. A summary of well information is presented in Table 1 below.

Well ID	DC-2
Date of Completion	January 11, 2014
Static Water Level (January 18, 2014)	6.70 m bgs
Recommended Maximum Pump Rate	1.6 L/s
Depth to Top of Screen	67.7 m bgs
Recommended Depth to Pump Intake	52.75 m bgs
Well Casing Diameter	152.4 mm
Screen Length	54.9 m bgs
Name of Drilling Contractor	Midnight Sun Drilling

**Note:** m bgs = metres below ground surface

Water samples collected by Tetra Tech EBA from DC-2 on January 21, 2014 were analyzed for typical drinking water screening parameters. All parameters were within *Guidelines for Canadian Drinking Water Quality* (GCDWQ); however, total dissolved solids (TDS) and dissolved iron exceeded the GCDWQ aesthetic objectives and the water contained high hardness.

If this well is to be developed as a community water supply, Tetra Tech EBA recommends that the submersible pump be installed at a depth of approximately 52.75 m bgs (1.5 m above the upper most water-bearing fracture zone) to maximize drawdown and well performance. The pump to be installed in the well should be capable of pumping at 1.8 L/s, overcoming a head of 46 m plus pipe friction losses and possible additional elevation gains to the water treatment plant. Long term pumping rates; however should not exceed the rated safe sustainable yield of the well of 1.6 L/s. DC-2 should be 'shock chlorinated' (disinfected) prior to commissioning. Any alterations to the well should be in compliance with the Public Drinking Water Regulations and the Canadian Groundwater Association's Well Construction Guidelines (CDWA).

Based on the results of the AWPP completed for DC-2, Tetra Tech EBA emphasises the following conclusions:

- Tetra Tech EBA identified the well as non-GUDI as the well is completed within a deep confined bedrock aquifer, all upper fractures were sealed off by the 152 mm and 203 mm casings, the well is significantly more than 60 m from the nearest surface water body, and DC-2 sampling results indicate that water quality is dissimilar to surface water obtained from Deep Creek;
- To date there has been no identified areas of potential contamination within the DC-2 well capture zone, and no indications of contamination in groundwater sampled from DC-2;
- Any release of contaminants within the identified capture zones would represent a potential risk to the aquifer and water quality of the Deep Creek Water Supply Facility; and
- The highest risks to DC-2 are from potential spills or releases within the capture zone areas up-gradient of DC-2 (Klondike Highway and Grizzly Valley);

In addition to the recommended risk reduction/ elimination strategies provided in Table 10, Tetra Tech EBA also recommends that YG complete the following:

- Implement contingency planning including emergency response actions and communication. YG should update the existing emergency and spill response plan identifying key personnel responsible to respond in the event of an occurrence or spill when changes in water treatment operator and/or community leadership changes occur;
- Complete regular tracking and monitoring of all well risks in the DC-2 capture zones (either with internal staff resources or outsourced to Tetra Tech EBA);
- Provide protection to the well capture zones by installing signs identifying entrances to the AWPP area;
- Review and update the AWPP on a regular basis. An annual review may be sufficient; however, thought should be given to an “as required” approach; and
- Incorporate this AWPP into the Deep Creek community development plan, and work with the community council to implement a Groundwater Protection Program for the community of Deep Creek and surrounding area. This Groundwater Protection Program should consist of the following:
  - Formal recognition and protection status for identified well protection zones such as those identified in this report;
  - Enforcement of well protection measures;
  - Restrictions on some land use activities within sensitive areas, well protection zones, designated recharge areas and areas of high vulnerability to contamination of the aquifer from surface sources (such as bedrock outcrops and faults); and
  - Hydrogeological assessment as a requirement of development for land use activities considered as higher risk, and including groundwater monitoring on and adjacent to specified sites as a condition of development.
- A response action plan and remedial action plans as a condition of development for some specified higher risk land uses.



## TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY .....</b>	<b>i</b>
<b>1.0 INTRODUCTION.....</b>	<b>1</b>
<b>2.0 SCOPE OF WORK.....</b>	<b>1</b>
<b>3.0 SITE DESCRIPTION .....</b>	<b>2</b>
3.1 Location of Study Area .....	2
3.2 Existing Water System.....	2
<b>4.0 HYDROGEOLOGY OF THE DEEP CREEK AREA.....</b>	<b>2</b>
4.1 Topography and Hydrology .....	2
4.2 Surficial and Bedrock Geology .....	2
4.3 Groundwater Flow .....	3
<b>5.0 FIELD PROGRAM .....</b>	<b>3</b>
5.1 Well Location .....	3
5.2 Well Drilling and Construction.....	4
5.3 Well and Aquifer Testing.....	5
5.3.1 Step Rate Pumping test.....	6
5.3.2 Constant Rate Pumping Test.....	6
5.3.3 Water Sample Collection .....	6
<b>6.0 HYDRAULIC TESTING RESULTS.....</b>	<b>6</b>
6.1 Pumping Test Results.....	6
6.2 Well Capacity .....	7
<b>7.0 WATER QUALITY RESULTS .....</b>	<b>8</b>
<b>8.0 GROUNDWATER UNDER THE DIRECT INFLUENCE OF SURFACE WATER AND AQUIFER VULNERABILITY .....</b>	<b>10</b>
<b>9.0 AQUIFER AND WELLHEAD PROTECTION PLAN.....</b>	<b>11</b>
9.1 Introduction .....	11
9.2 Stage One – Risk Framework.....	12
9.2.1 Risk Approach .....	12
9.3 Responsible Parties.....	12
9.4 Risk Management Team.....	12
9.5 Risk Tolerance .....	12
<b>10.0 STAGE TWO – RISK ASSESSMENT .....</b>	<b>12</b>
10.1 Well Capture Zone Assessment .....	12
10.2 Identification of Risks in Well Capture Zones .....	13
10.3 Potential Receptors .....	14
10.4 Identification of Risk Scenarios.....	14
10.5 Contaminated Sites and Spills Search, Government of Yukon .....	14

10.6	Site Reconnaissance .....	14
10.7	Air Photo Review .....	15
10.8	Zone 1 – 90 Day Travel Time (Sanitary Protection Zone) .....	15
10.9	Zone 2 – One Year Travel Time .....	16
10.10	Zone 3 – Seven Year Travel Time (Ultimate Capture Zone) .....	16
10.11	Risk Evaluation and Mapping .....	16
<b>11.0</b>	<b>STAGE THREE – RISK MANAGEMENT .....</b>	<b>19</b>
11.1	Risk Management Strategy .....	19
11.2	Risk Reduction Plan .....	19
11.3	Risk Monitoring .....	20
<b>12.0</b>	<b>CONCLUSIONS AND RECOMMENDATIONS.....</b>	<b>21</b>
12.1	Conclusions .....	21
12.2	Recommendations.....	22
<b>13.0</b>	<b>CLOSURE.....</b>	<b>24</b>
	<b>REFERENCES .....</b>	<b>25</b>

**LIST OF TABLES IN TEXT**

Table 1:	Well Information Summary Table .....	i
Table 3:	Summary of Well Construction Details .....	5
Table 4:	Pumping Test Results .....	7
Table 5:	Summary of Safe Yield Calculations .....	8
Table 7:	Key Water Quality Design Parameters .....	9
Table 8:	Exposure and Hazard Categories .....	17
Table 9:	Risk Database and Risk Evaluation .....	18
Table 10:	Risk Reduction/Elimination Strategies to be Considered.....	20

**APPENDIX SECTIONS**

**TABLES**

Table 2	Summary of Existing Water Wells and Groundwater Monitoring Wells in the Vicinity of DC-2.
Table 6	Summary of Water Quality Results for Test Well DC-2 and Deep Creek

**FIGURES**

Figure 1	Site Location Plan
Figure 2	Existing Site Conditions
Figure 3	Observed Drawdown During Pumping Tests
Figure 4	Extrapolation of Drawdown During Constant Rate Pumping Test to 100 Days
Figure 6	Local Topography and Aquifer Capture Zones

## APPENDICES

- Appendix A Tetra Tech EBA's General Conditions
- Appendix B DC-2 Well Log
- Appendix C Driller's Well Log
- Appendix D Step and Constant Rate Pumping Test Manual Data and Interpretation
- Appendix E DC-2 Laboratory Results
- Appendix F Yukon Contaminated Site Records and Yukon Government Correspondence

## **LIMITATIONS OF REPORT**

This report and its contents are intended for the sole use of Government of Yukon and their agents. Tetra Tech EBA Inc. Government of Yukon does not accept any responsibility for the accuracy of any of the data, the analysis, or the recommendations contained or referenced in the report when the report is used or relied upon by any Party other than Government of Yukon, or for any Project other than the proposed development at the subject site. Any such unauthorized use of this report is at the sole risk of the user. Use of this report is subject to the terms and conditions stated in Tetra Tech EBA's Services Agreement. Tetra Tech EBA's General Conditions are provided in Appendix A of this report.

## 1.0 INTRODUCTION

Tetra Tech EBA Inc. (Tetra Tech EBA) was retained by Government of Yukon (YG), Community Services, Infrastructure Development Branch (YG-IDB) to prepare a well completion report and an aquifer and wellhead protection plan (AWPP) for well DC-2, which is proposed to serve a new Deep Creek Water Supply Facility located in Deep Creek, Yukon. This report has been prepared as per YG Contract C00016678.

Previous work conducted by Tetra Tech EBA relating to the Deep Creek Water Supply facility included:

- Preparation of the *Deep Creek Region Water Supply Feasibility Study* (Tetra Tech EBA 2012);
- Coordination of drilling, construction and testing two new cold water test wells in Deep Creek (DC-1) and Grizzly Valley (GV-1) in 2012; and
- Preparation of Completion reports for DC-1 and GV-2 (Tetra Tech EBA 2012).

The intent of YG-IDB is to develop one of the test wells for a water supply facility to be used as a public fill point serving Deep Creek and Grizzly Valley subdivisions, residents of the Ta'an Kwach'an First Nation (TKFN) and Horse Creek (Service Area).

Based on a decision by YG-IDB, Deep Creek subdivision was selected as the preferred location for a water supply facility. The first test well drilled in Deep Creek subdivision (DC-1) was completed in fractured bedrock aquifers. DC-1 was identified as being potentially Groundwater Under the Direct Influence (GUDI) of surface water based on a Phase 1 initial GUDI screening due to bedrock fractures in the upper 15 m of the well. Furthermore, although well DC-1 was drilled significantly greater than the required 120 m set back requirement from the Old Deep Creek Dump; and is 200 m slightly up-gradient of the dump, based on the geology encountered, it was determined that DC-1 could potentially be influenced by historical dumping practices during pumping conditions because of complex bedrock hydrogeology. As further work would be necessary to verify whether this was a legitimate concern, YG-IDB elected to drill a second test well (DC-2) in the Deep Creek area.

Well DC-2 was subsequently drilled on the opposite side of Deep Creek from the Old Deep Creek dump; the creek is considered a discharge area and flow divide thereby significantly reducing risk posed by the dump. This report outlines the well completion for DC-2, aquifer and wellhead conditions, the theoretical well protection area, potential contaminants of concern and recommendations for protecting the potable water supply.

## 2.0 SCOPE OF WORK

The scope of work for this phase of the project included the following tasks which are documented in this report:

- Review of background information and recommendations on well location for DC-2;
- Prepare well drilling, construction, and testing specifications for DC-2;
- Field review of drilling and installation of well DC-2;
- Coordinate and field review of hydraulic testing of DC-2;
- Collect and submit water samples from DC-2;
- Analyze and interpret data from the drilling and pumping test program; and

- Prepare a well completion report and Aquifer and Wellhead Protection Plan for DC-2, documenting potential contaminants of concern within the capture zone and provide risk management strategies.

The following sections provide further detail regarding the scope of work described above.

## **3.0 SITE DESCRIPTION**

### **3.1 Location of Study Area**

Deep Creek test well DC-2 is located southwest of Lake Laberge adjacent to Deep Creek, Yukon, approximately 45 km north of Whitehorse, Yukon. DC-2 is accessed via Deep Creek Road on the east side of the Klondike Highway. The nearest water course to DC-2 is Deep Creek, which is approximately 200 m to the north. A site location plan is provide in Figure 1.

### **3.2 Existing Water System**

Residents of the service area are currently supplied potable drinking water by a variety of sources including private wells, trucked bulk delivery from Whitehorse to domestic water tanks, and personal collection and hauling from Whitehorse.

## **4.0 HYDROGEOLOGY OF THE DEEP CREEK AREA**

The hydrogeological regime of the Deep Creek area has been interpreted from data collected from a variety of sources including lithology information presented on well logs, groundwater level measurements taken during field investigations, pumping test results, water quality data, and available topographical, geological and surficial mapping records. Table 2, attached, summarizes well information for existing water wells and groundwater monitoring wells identified by Tetra Tech EBA in the vicinity of DC-2.

### **4.1 Topography and Hydrology**

Deep Creek is located between Pilot Mountain to the west and Lake Laberge to the east. The topography in the Deep Creek region gently slopes towards Lake Laberge; however, the local topography surrounding DC-2 slopes south-southeast (based on a topographic survey, within a 50 m radius of DC-2).

Deep Creek crosses the Klondike Highway approximately 320 m southwest of the junction to Deep Creek Road and flows east into Lake Laberge.

### **4.2 Surficial and Bedrock Geology**

Geological information was obtained through site visits, review of topographic and geological maps (from the Canadian and Yukon Geological Survey's) and previous reports and maps. The Deep Creek area has undergone several episodes of glaciation, the most recent being the Quaternary McConnell glaciation. The topography and surficial geology of the Deep Creek area have been heavily influenced by glacial erosion and deposition.

The surficial geology in the Deep Creek area is characterized by both outcropping bedrock and glacial deposits. Glacial deposits are varied, including till, valley bottom complexes composed of alluvial, colluvial and glacial deposits, meltwater channels and glaciofluvial complexes. The bedrock is comprised of sedimentary members of the lower to middle Jurassic Laberge Group (around 160 to 200 myo) and Lower Jurassic Nordenskjold Group (around 175 to 200 myo). Laberge Group rock types in the study area are mapped as sedimentary rock, with interbedded mudstones, siltstones and sandstones and a conglomerate member. Nordenskjold Group rock types

occurring in this area are mapped as sedimentary rocks with volcanic beds, dacite, tuff, sandstone, and conglomerate. Rock types encountered during drilling were members of the Laberge group.

Tetra Tech EBA obtained drillers field reports from 13 wells drilled within the Deep Creek area between 1970 and 2012. Logs of wells in the Deep Creek region show bedrock at depths typically between 4.5 m and 17 m, although bedrock outcropped at two well locations. In the Deep Creek region, bedrock was typically overlain by gravelly clay/silt (inferred to be till) with gravel or sand logged at surface in several logs.

### 4.3 Groundwater Flow

The regional groundwater flow regime is interpreted to consist of groundwater recharging via infiltration in the upland areas to the west of DC-2 and groundwater discharging into Deep Creek and Lake Laberge. The regional groundwater flow direction was interpreted to be in an east, northeast direction, which generally corresponds to topography.

As noted in Table 2, the static water level in the various bedrock wells in the Deep Creek ranges from 3.3 m to 10.4 m below ground level. The estimated yield from these wells varies from 0.1 L/s to 1.7 L/s. Yield from bedrock aquifers can be highly variable and is dependent upon the degree of fracturing and fracture connectivity.

## 5.0 FIELD PROGRAM

### 5.1 Well Location

The well location for DC-2 was selected in accordance with the requirements outlined in the guidelines by the Canadian Groundwater Association and the Yukon *Drinking Water Regulation* (Public Health and Safety Act, Part I – Large Public Drinking Water Systems). These guidelines and regulations require the well to be located:

- 60 metres from any part of a sewage disposal system, or other potential sources of pollution that may pose a health and safety risk;
- 120 metres from a solid waste site or dump, and cemetery; and
- 300 metres from a sewage lagoon or pit.

The drilling site was selected in collaboration with YG-IDB to comply with setback distances specified above and considering existing geological and hydrogeological information; and proximity to the proposed site infrastructure. The well location is shown on Figure 2. Relevant comments regarding the site selected for DC-2 are below:

- The well location meets all required set-back distances from sewage disposal systems, potential sources of pollution that may pose a health and safety risk, solid waste site or dump, cemetery and sewage lagoon or pit;
- The well is more than 480 m from the old Deep Creek Dump and across Deep Creek, which is interpreted to be a groundwater discharge area flow divide;
- There is currently no development within 200 m of the well site; the closest development is the Bahai Centre which is about 200 m down-gradient and on the other side of the Deep Creek flow divide;
- Deep Creek is more than 120 m from the well at its closest location; and
- There were no bedrock outcrops located within 60 m of the well; the closest bedrock outcrop was identified to be more than 140 m from DC-2.

## 5.2 Well Drilling and Construction

DC-2 was drilled from January 7 to 11, 2014 by Midnight Sun Drilling, Yukon, using an air rotary drill rig. During the drilling, a Tetra Tech EBA hydrogeologist monitored drilling operations and recorded subsurface conditions encountered. The well log summarizes the subsurface conditions encountered at DC-2 is found in Appendix B.

A 305 mm (12") casing was initially advanced to a depth of 6.1 m bgs to establish the outer annulus for the sanitary seal. Next, a 203 mm (8") casing was advanced to a depth of 13.1 m bgs, where a shallow unconfined aquifer was encountered at the bedrock interface with a yield of approximately 30-40 USgpm. The drillers continued to drill a 203 mm (8") open hole to a depth of 17.1 m bgs, followed by a 152 mm (6") open hole to a depth of 22.6 m bgs. The well was subsequently developed by airlifting and surging for eight hours. At the end of the development period, the water was very turbid and was not suitable for potable use.

The 203 mm (8") casing was advanced to 15.3 m into competent bedrock, which cut off flow from fractures in the weathered bedrock. In order to ensure all fractures would be sealed off, the hole was filled with bentonite chips to a depth of 14.8 m bgs. A 152 mm (6") casing was then installed in the well. The annulus between the 152 mm and 203 mm casing was filled with bentonite chips to surface. The 152 mm casing was then advanced into competent bedrock at a final depth of 17.1 m bgs.

To establish the outer sanitary seal, the 305 mm diameter casing was removed while continuously pumping liquid bentonite grout via tremmie pipe between the annulus of the 305 mm and 203 mm diameter casings. The sanitary seal was established continuously from 6.1 m bgs to ground surface.

DC-2 was completed to a depth of 122.5 m. Construction details are included in Table 3 and the Driller's Well Log is attached in Appendix C. The well was developed for seven hours by airlifting and surging. The well development was stopped after seven hours when the water was visibly clear and the field turbidity measurements were approximately 10 NTU.

A summary of well construction details is provided as Table 3.



<b>Table 3: Summary of Well Construction Details</b>	
<b>Date of Construction:</b>	January 7 – 11, 2014
<b>Owner of the well:</b>	Government of Yukon
<b>GPS Coordinates (NAD83):</b>	UTM Zone 8N 0488349.79 E 6770522.59 N
<b>Location of well on the property:</b>	See Figure 2
<b>Drilling contractor:</b>	Midnight Sun Drilling, Whitehorse, Yukon
<b>Method of construction:</b>	Air Rotary
<b>Description, depth, and thickness of geologic materials encountered during construction:</b>	See well log in Appendix B and drillers well log in Appendix C
<b>Depth and diameter of the well:</b>	Total depth of well is 122.5 m. Nominal diameter of steel casing to 15.3 m bgs: 203 mm (8"). Nominal diameter of steel casing to 17.1 m bgs: 152 mm (6"). Nominal diameter of PVC liner to 121.0 m bgs: 127 mm (5").
<b>Type of casing materials and thickness:</b>	Steel casing: 0.250" (6.35 mm) wall thickness; Schedule 40 PVC liner
<b>Static water level:</b>	6.70 m bgs (January 18, 2014)
<b>Type, size, length and location of the screen:</b>	Slotted PVC liner: 0.020" slot size; 67.7-122.5 m bgs
<b>Major water-bearing fractures (m bgs):</b>	54.3, 92.0, and 109.7
<b>Location, type and thickness of grout sealant placed around the well:</b>	Bentonite seal was placed in the annulus between the 203 mm (8") casing and native sediments. Seal is completed from grade to 6.1 m (20 ft) bgs with a radial thickness of 51 mm (2"). Bentonite chips were also placed in the annulus between the 152 mm (6") casing and the 203 mm (8") casing from a depth of 17.1m bgs to surface.

### 5.3 Well and Aquifer Testing

Hydraulic testing was conducted by Arctic Sky Welding and under field review by Tetra Tech EBA on January 18 - 22, 2014. A temporary submersible pump was installed in the well at a depth of approximately 60 m. Solinst dataloggers were deployed in DC-1 and DC-2 to monitor the groundwater level during hydraulic testing. Water levels were also measured manually on specified intervals using a water level sounder.

Arctic Sky Welding monitored flow during the pumping test using a graduated flow meter. Flow was also confirmed by measuring the time to fill a 19 L bucket. Water removed from the well during hydraulic testing was pumped to an area approximately 60 m south of the well and disposed of via infiltration.

Manual data collected during the step and constant rate pumping tests are included as Appendix D.

### 5.3.1 Step Rate Pumping test

A step rate pumping test was conducted to determine the optimal rate at which to perform the constant rate pumping test. The step rate test at DC-2 consisted of four 60 minute steps at rates of 0.4 L/s (6 USgpm), 0.8 L/s (12 USgpm), 1.1 L/s (17 USgpm), and 1.6 L/s (25 USgpm). The results from the step rate test are presented in Figure 3.

### 5.3.2 Constant Rate Pumping Test

A constant rate pumping test was conducted after 98% recovery of the groundwater level from the step rate pumping test (see Figure 3). Based on the step rate test results and the pump capacity, it was determined that DC-2 could be pumped at 1.4 L/s (23 USgpm) for the 48 hour constant rate test.

### 5.3.3 Water Sample Collection

Tetra Tech EBA collected water samples from well DC-2 at the end of the constant rate pumping test on January 21, 2014. The samples were collected in laboratory supplied sample containers in accordance with laboratory sampling procedures. Samples were submitted to ALS in Whitehorse for detailed potability analysis. Samples were also shipped on ice by air cargo to Exova in Surrey, B.C., for trihalomethane (THM) formation potential. The ALS and Exova laboratories are accredited ISO/IEC 17025 testing laboratories.

Samples were also submitted to the Saskatchewan Research Council (SRC) Analytical Lab to test for radiological parameters. Samples for bacteriological analysis were submitted to Environmental Health Services, Whitehorse within the 24-hour holding time.

## 6.0 HYDRAULIC TESTING RESULTS

### 6.1 Pumping Test Results

The observed drawdown in DC-2 during the step rate and constant rate pumping tests and the subsequent recovery periods are shown in Figure 3. After 48-hours, the drawdown in the well during the constant rate pumping test was 25.05 m.

Recovery of the groundwater level in the pumping well to within about 95% of the initial static water level occurred in approximately 15-hours following the constant rate test.

The drawdown data during the pumping test were analyzed using the Theis recovery and Cooper-Jacob Straight-Line Time-Drawdown Methods (e.g., Fetter, 2001). Both interpretation methods were applied using the software AquiferTest™ (by WHI, v2011.1), which was used to analyze the pumping test data (see Appendix D).

The results of the pumping test are presented in Table 4. The geometric mean hydraulic conductivity interpreted from the test was  $1.1 \times 10^{-6}$  m/s, is typical for fractured sedimentary bedrock encountered in the test well. This value represents the bulk hydraulic conductivity assuming an aquifer thickness of 68 m corresponding to the saturated thickness from the uppermost saturated fracture zone to the base of the well.

<b>Table 4: Pumping Test Results</b>			
<b>Well</b>	<b>Method</b>	<b>T</b>	<b>K</b>
		<b>[m<sup>2</sup>/s]</b>	<b>[m/s]</b>
DC-2	Theis Late Recovery	8.0E-05	1.2E-06
	Cooper-Jacob	7.0E-05	1.0E-06
	Geometric Mean	7.5E-05	1.1E-06

**Notes:** T- transmissivity  
 K- Hydraulic Conductivity

## 6.2 Well Capacity

The safe yield of a well was determined by Tetra Tech EBA based on the available drawdown above the pump intake, the capacity of the screen installed in the well, and the transmissivity of the aquifer around the well screen.

To calculate the safe yield of a well, the 100-day specific capacity was multiplied by the safe available drawdown. The 100-day specific capacity of the well (at a given pumping rate) is based on the projection of the observed drawdown at the end of the constant rate pumping test extrapolated to 100 days as shown on Figure 4. This conservatively assumes that the well would be continuously pumped at the same rate for 100-days with no recharge to the aquifer. The safe available drawdown of the well is determined by applying a safety factor of 70% to the physical available drawdown after an allowance has been made for seasonal fluctuations in static water level. The water level in the well should also not be lowered to below the upper most water-bearing fractures of the well (see Table 3). Therefore, the lowest recommended water level during pumping is about 52.75 m bgs (i.e., 1.5 m above the water-bearing fracture at 54.3 m bgs) at which depth the pump should be installed.

The safe yield of a well can also be limited by what the well screen is capable of delivering based on the maximum recommended screen entrance velocity. Based on 55 m (180 feet) of 20-slot screen, with four rows of slots, and a maximum pumping rate of 1.8 L/s the screen entrance velocity is estimated to be 0.002 m/s. A velocity of 0.002 m/s will be laminar and will not be limited by the well screen. Table 5 details the safe yield calculations for the well.

<b>Table 5: Summary of Safe Yield Calculations</b>			
<b>Well Parameter</b>	<b>Value</b>	<b>Unit</b>	<b>Key</b>
Constant Rate Pumping Test Discharge Rate	1.4	L/s	a
Projected 100-Day Drawdown	28	m	b
Projected 100-Day Specific Capacity	0.05	L/s/m	c=a/b
Lowest Expected Seasonal Water Table (1 m below static)	7.70	m	d
Recommended Depth of Pump Intake	52.75	m	e
Available Drawdown	45.05	m	f = e-d
Safety Factor	70	%	g
Safe Available Drawdown	31.67	m	h = f x g
<b>Theoretical Safe Yield Based on Constant Rate Pumping Test</b>			
Theoretical Safe Sustainable Yield	1.6	L/s	i = c x h
Theoretical Safe Sustainable Yield	25.4	USgpm	

The long-term sustainable safe well yield determined by this process is a conservative estimate and is unlikely based on the projected system demands. The proposed public-fill point system for DC-2 will likely encounter maximum flows during weekends with periods of stagnation and recovering during weekdays. Durations of higher flows can be sustained from this well as long as the average usage is less than 1.6 L/s. Based on this type of system usage, the maximum pumping rate for a 48-hour period is recommended to be 1.8 L/s based on the results of the constant rate test.

## 7.0 WATER QUALITY RESULTS

Groundwater analytical results and a comparison with the GCDWQ are presented in Table 6, attached. The laboratory reports from DC-2 and certificates are included as Appendix E. Table 7 provides a summary of key water quality design parameters.

Based on analytical results from the sample collected at DC-2 on January 21, 2014, the water quality results met GCDWQ for all parameters tested, except for TDS, iron and hardness, which exceeded aesthetic objectives (AO). When compared to the water quality encountered at DC-1, the key water quality design parameters are very similar.

Parameter	GCDWQ	DC-2 Water Quality Results (January 21, 2014)
Iron	<0.3 mg/L	<b>0.344 mg/L</b>
Manganese	<0.05 mg/L	0.0102 mg/L
Hardness (as CaCO <sub>3</sub> )	80 to 100 mg/L (suggested guideline)	433 mg/L
TDS	<500 mg/L	<b>634 mg/L</b>
Gross Alpha	<0.5 Bq/L	<b>0.74 Bq/L</b>
Radium-226	<0.2 Bq/L	<0.05 Bq/L

Notes: **Bold** values exceed GCDWQ

The total dissolved concentrations of iron, manganese, calcium and magnesium (hardness) contribute to the high TDS. The iron concentration slightly exceeds the AO of 0.3 mg/l. Iron is common in groundwater supply and is naturally occurring. There are no health impacts associated with the presence of iron; however, it imparts taste, which will deposit or stain storage and plumbing fixtures and will stain clothing when used for laundry.

There is no AO for hardness; however, the GCDWQ recommends levels between 80 and 100 mg/L (as CaCO<sub>3</sub>) to provide acceptable balance between corrosion and incrustation. Hardness at DC-2 at the time of sampling was 433 mg/L (as CaCO<sub>3</sub>). Residents using water with high hardness face issues with scaling of plumbing features and more soap/detergent is required for washing, however hardness issues can be addressed using point of use water softening units.

Gross alpha and beta are used to screen for the presence of radioactivity in water. Sample results for radiological parameters were above the GCDWQ for gross alpha (0.74 Bq/L), but below the GCDWQ for gross beta. SRC recommended further analysis to determine the concentration of radium-226 radionuclides, as radium has the most stringent maximum acceptable concentration (MAC) of radiological parameters contributing to the gross alpha concentration. The resulting concentration in DC-2 was below the detection limit (<0.05 Bq/L). Because this result is below the guideline for radium-226 (0.2 Bq/L), the source of the gross alpha remains unknown. However, all other species that contribute to the gross alpha have much higher MACs (greater than 5 Bq/L). As the concentration of the radium-226 was below the detection limit and the total gross alpha concentration does not exceed any MAC for individual species potentially contributing to the concentration of gross alpha, these results confirm that there are no exceedances of any radiological parameters in the samples collected from DC-2.

The lab turbidity measurements from water sample obtained from the supply well was 3.9 NTU. During the sampling event conducted on January 21, 2014, the field turbidity was measured at 0.9 NTU. This measurement is significantly lower than the turbidity measured at the lab and demonstrates that much or all of the turbidity is likely the result of precipitate formation. It should be noted that lab turbidity is often elevated over field turbidity due to precipitate formation prior to analysis. According to Health Canada, the nature of turbidity and its health implications vary with the type of source water. Turbidity in surface and groundwater that comes into contact with surface water (referred to as groundwater under the direct influence of surface water), however, is generally organic in nature and may contain toxins, harbour pathogens, or lead to the formation of THMs. Turbidity in secure groundwater supplies (e.g., not under the influence of surface water) is generally non-organic and should pose no health threat. The health-based guideline and target for turbidity therefore apply only to surface water sources and groundwater under surface water influence. As this well is considered to be secure, the turbidity is not considered to be an issue.

A bacteriological sample taken from the well was submitted to the Environmental Health Services department on January 21, 2014. Sample results showed no presence of total coliforms or *E. coli* on the date sampled.

As part of the envisioned water treatment system for DC-2, chlorine will be used for primary and secondary disinfection. Organics present in water may have the potential to react with chlorine to produce trihalomethanes (THMs).

According to Health Canada, THMs can affect the function of liver and kidneys, and has been linked to colorectal cancer. In order determine if the water from DC-2 has the potential to react with chlorine to generate THMs, a spike concentration of chlorine was added to the water sample collected from DC-2. The sample was then incubated for a period of seven days. The concentration of total THM was 0.023 mg/L, which is below the MAC of 0.1 mg/L.

All hydrocarbons analysed were below detection limit and in consideration with the other water quality data (metals, nutrients) there was no indication of impact of the former landfill on the water quality from the test well (as expected given the distance and the Creek flow divide between the well and the dump site).

## 8.0 GROUNDWATER UNDER THE DIRECT INFLUENCE OF SURFACE WATER AND AQUIFER VULNERABILITY

Well water or groundwater under the direct influence of surface water refers to groundwater sources that have a direct hydraulic connection to surface water sources and are therefore vulnerable to contamination by surface water organisms. The implication of a well being classified as GUDI means that the well water source requires water treatment equivalent to that required for surface water sources.

A shallow fractured bedrock aquifer was encountered at DC-2 from about 13.1 m to 15.2 m bgs. This upper zone, due to its shallow depth may have been under the direct influence of surface water. The well DC-2, however, was drilled through this shallow aquifer zone and a continuous steel casing was advanced into competent bedrock, and a seal was subsequently placed around the casing within the competent bedrock. During drilling, the borehole was then advanced open hole, and the bore remained dry until 54.3 m below grade where the next fractured zone aquifer was encountered.

The water supply well, DC-2, is completed in the deep confined or semi confined bedrock aquifer. Water bearing fractures were encountered between 54.3 and 121.0 m bgs. Protection is provided by overburden sediments to 10.5 m below grade, and a thick layer of competent bedrock extending from 17.1 m bgs to the first water bearing fracture at 54.3 m bgs. The thick competent bedrock layer; and properly constructed well completed with a sanitary seal and a bedrock seal decreases the potential for surface water and surface sources of contamination to infiltrate though and impact the water supply at DC-2.

Tetra Tech EBA conducted a Phase 1 Initial GUDI screening in accordance with the Yukon GUDI Assessment Guideline, and determined that Well DC-2 is non-GUDI according to the guidelines outlined in GY (2006). The following criteria were considered in the Phase 1 Initial GUDI screening:

- **Water Source Location or Type:** The well is not considered to be a vulnerable type as the production zone is significantly deeper than 15 m below grade, the well is completed in a confined or semi confined aquifer, and there are no exposed bedrock outcrops within at least 200 m of the well. To ensure that all shallow fractures in the fractured bedrock were sealed off, the 203 mm casing was advance to 15.2 m and the 152 mm casing was advanced to 17.1m to competent bedrock. The borehole remained dry during drilling, until deep fracture zones were intersected. The annulus between the 152 mm and 203 mm casings was filled with bentonite chips.

- **Proximity to Surface Water:** The well is about 120 m from Deep Creek, the nearest surface water source; significantly exceeding the trigger of 60 m.
- **Well Construction:** The well was constructed in general accordance with the Guidelines for Water Well Construction published by the Canadian Ground Water Association; and
- **Water Quality:** The DC-2 water supply has significantly different chemistry based on the review of surface water data obtained from Deep Creek in January, 2014. Water quality in samples obtained from DC-2 show much higher mineralization, suggesting long residency time in the subsurface, than the water quality in Deep Creek. The water sample collected from DC-2 following the pump test was negative for total coliforms and *E. coli*.

Additional considerations that were made as part of the initial GUDI screening include:

- Based on the average daily pumping rate and corresponding pumping water level at DC 2 and the expected highest water elevation at Deep Creek, the horizontal groundwater travel time from the creek to DC-2 was estimated to be greater than 90 days. Given that the well is completed in a deep confined aquifer, we expect that the travel time would be significantly higher than 90 days (a suggested threshold value in the Phase 2 Yukon GUDI assessment guidelines).

Based the above considerations in accordance with the Yukon GUDI assessment guideline, under the proposed pumping rates (equal to or less than 0.35 L/s average pumping) DC-2 is considered non-GUDI.

## 9.0 AQUIFER AND WELLHEAD PROTECTION PLAN

### 9.1 Introduction

The objective of the Aquifer and Wellhead Protection Plan (AWPP) for DC-2 is to provide practical protective measures to identify and pragmatically manage activities within the well capture zone and recharge areas for the Deep Creek community supply well, DC-2, with the intention of reducing risks to the water supply source. This plan is one important step in a multi barrier approach to protect the valuable resource, the health and safety of the community, and to protect the investment in water supply infrastructure. The AWPP is a living document which should be updated based on activities around the community wells that might result in additional risks, or when risks have been addressed.

Risk-based AWPPs are established to identify, manage, mitigate, monitor, and communicate risks to quality and quantity of water supplying wells used by humans, animals (e.g., livestock), plants (e.g., irrigation) or for industrial process water. Groundwater entering a well comes from an area that is defined as a capture zone or recharge area for that well. The basic objective of risk-based AWPP is to provide realistic protective measures to prudently manage activities in the capture zone or recharge area of a well or well field to reduce risks to a water supply.

The AWPP for Deep Creek water supply well DC-2 has been developed to include the following three stages:

- Stage One – Risk Framework;
- Stage Two – Risk Assessment; and
- Stage Three – Risk Management.



## 9.2 Stage One – Risk Framework

### 9.2.1 Risk Approach

The initial step towards a risk-based AWPP is to determine the appropriate risk approach for the project. Risk identification can be qualitative (a descriptive assessment of the risk elements; hazards, exposure likelihood and receptor) or quantitative, (i.e., based on probabilistic mathematical analysis of the risk elements). Due to the limited site information and resources available for this project, a qualitative risk approach was deemed appropriate.

### 9.3 Responsible Parties

The responsible party in the context of the risk-based AWPP is the Government of Yukon.

### 9.4 Risk Management Team

One of the initial steps to successful development and implementation of an AWPP is to form a risk management team comprising representatives from the owner, technical advisors, and any key stakeholder groups such as domestic and community well users in the area. The risk management team proposed for this AWPP consists of a selection of YG-IDB representatives, the Association of Yukon Communities, the TKFN, water users, future water system operators, and Tetra Tech EBA (the technical advisor).

### 9.5 Risk Tolerance

For this project, risk tolerance is a measure of the acceptable level of risk by the risk management team or water supplier. A risk-tolerant owner would be able to accept or transfer some level of risk, while a risk-adverse owner would seek to eliminate even the lowest level of risk to the water supply. Based on discussions with YG, Tetra Tech EBA considers the Owner to be risk-adverse.

## 10.0 STAGE TWO – RISK ASSESSMENT

### 10.1 Well Capture Zone Assessment

The first technical step in developing this AWPP was to identify the capture zone (the geographic area that contributes groundwater to a well) for DC-2. The capture zone is a key element in an AWPP, since only groundwater within this zone reaches the well. The size and shape of the capture zone depends upon the hydrogeological setting and the design and operational characteristics of the water supply well.

Due to the complex hydrogeology associated with a fractured bedrock aquifer, a conservative capture zone must be considered. To fully characterize a fractured bedrock aquifer, a great deal of geological and hydrogeological data is required. In the absence of comprehensive hydrogeological data, simplifying assumptions must be made. In order to determine the capture zone of DC-2, the following assumptions were made:

- Deep Creek can be considered a natural groundwater flow boundary. During winter conditions, flow was observed in the creek (Deep Creek), indicating that the creek receives base flow from surrounding aquifers and acts as a natural flow divide. This is also supported by the fact that no hydraulic response was observed at DC-1, north of Deep Creek, during the hydraulic testing conducted on DC-2;
- Topography was considered to estimate a logical maximum width of the watershed and capture zone, which also coincides with about a one year travel time;



- Two scenarios of groundwater transport in the bedrock aquifer were considered:
  - Scenario 1: The bulk hydraulic conductivity was calculated to be  $1.1 \times 10^{-6}$  m/s, assuming the aquifer extended from the first fracture at 54.3 m bgs to the bottom of the well at 122.5 m bgs. The associated porosity for this Scenario would have a very low porosity, which we assumed to be 1% or 0.01.
  - Scenario 2: As groundwater may travel much faster through permeable bedrock fractures, the hydraulic conductivity for Scenario 2 was adjusted assuming that the majority of the groundwater flow occurs in fractures and fault zones within the bedrock. Assuming a total thickness of faults and fractures to be 1.0 m and an aquifer transmissivity to be  $7.5 \times 10^{-5}$  m<sup>2</sup>/s, the adjusted hydraulic conductivity of the fractured bedrock is  $7.5 \times 10^{-5}$  m/s. This hydraulic conductivity is similar to the maximum typical value for fractured sedimentary rock (Freeze & Cherry, 1979). The associated porosity, of a highly fractured zone was estimated to be 10% or 0.1.
- The hydraulic gradient was estimated to be 0.06 m/m based on the topography of the area, and elevations of surface water bodies.

The distance to the 90 day, one-year and ultimate capture zone were estimated using Darcy's law, by the following formula (Well Protection Toolkit):

$$d_{TOT} = \frac{tKi}{n}$$

Where:  $d_{TOT}$  = the distance (m) representing the 90 day, one year, and ultimate capture zone:

t = time of travel (90 days, one-, five- years etc.)

K = hydraulic conductivity ( $1.1 \times 10^{-6}$  m/s for scenario 1 and  $7.5 \times 10^{-5}$  m/s for scenario 2)

i = hydraulic gradient (0.06 m/m for both scenarios)

n = porosity of the aquifer (0.01 for scenario 1 and 0.1 for scenario 2)

We then used the average travel distance from the two methods (about 800 m/ year) to establish the 90 days, one year, and ultimate capture zones as indicated on Figure 6.

## 10.2 Identification of Risks in Well Capture Zones

The AWPP defines areas within the well capture zones, which are determined by the level of control required (and thus groundwater resource management strategies) to safeguard a water supply, including:

- Zone 1 – between 0 and 90 days to reach DC-2;
- Zone 2 – one year or less to reach DC-2; and
- Zone 3 – Between one year and seven years to reach DC-2; also interpreted to be the ultimate capture zone based on surface water boundaries.

### 10.3 Potential Receptors

Potential receptors are the users of the water supply facility, namely the residents of the service area (Deep Creek and Grizzly Valley subdivisions, residents of the Ta'an Kwach'an First Nation (TKFN) and Horse Creek). Other potential receptors include fire protection areas that may be serviced by the firefighting water stored from DC-2.

### 10.4 Identification of Risk Scenarios

Risk can be defined as the potential for exposure of a receptor to a hazard. Risk assessment is the process of evaluating the consequences of hazard severity and likelihood of exposure, then evaluating, ranking and mapping the identified risk scenarios. The three key elements of risk: exposure, hazard, and receptors which, when combined, generate the definition of risk. Risk can be effectively removed or reduced to acceptable levels if any of the three elements are eliminated or blocked. Potential for exposure can be expressed in terms of the likelihood of a receptor (i.e. humans, animals and plants) coming into contact with a hazard. Hazards can be categorized in terms of severity (contaminant toxicity). To be practical and conservative, the evaluation of a hazard in this analysis assigns the highest potential concern that may be presented at the well head for that hazard (i.e. no retardation or reduction in hazard severity along its travel path to the well).

In order to evaluate potential risks to the Community Wells, potential sources of contamination (existing and future) within the capture zone were assessed. Tetra Tech EBA used various methods to identify Areas of Potential Environmental Concern (APECs) near and within the AWPPs, including:

- Completing a search (5 and 10 km radius of the Site) for spill records within Government of Yukon, Department of Environment, Environmental Programs Branch;
- Completing a site investigation and ground reconnaissance of the area surrounding DC-2 up to Deep Creek and Deep Creek Road; and
- Reviewing air photos from the 1950's to present, and current Google Earth images to record changes to surrounding land use and current land uses in surrounding areas.

### 10.5 Contaminated Sites and Spills Search, Government of Yukon

YG, Department of Environment, and Environmental Programs Branch has maintained the Yukon Spills Report Centre since 2001; however, Environment Canada has transferred some of their Yukon contaminated sites and spill database records to YG Environment dating back to the late 1980's for certain areas. A large area search (10 km radius of the site) was conducted for contaminated sites and spills. The search conducted by YG Environment in July 2013 identified five records located between 5 and 10 km from the site; however, only results within a 5 km distance up-gradient of the site were considered to potentially be APECs. One record (Yukon Contaminated Site ID Number LA002) was identified approximately 5.5 km northwest of the site. An abandoned military vehicle was originally reported at this location in 1989. The site was assessed in 2005 and remediated in 2008. Yukon Contaminated Site Records and YG correspondence are presented in Appendix H.

### 10.6 Site Reconnaissance

Tetra Tech EBA conducted a site reconnaissance on July 22, 2013 and November 5, 2013 to document the existing conditions in the area bound by Deep Creek Road, Deep Creek and up-gradient of DC-2. This area is primarily forested with a power transmission line approximately 350 m northwest of DC-2. Trees and brush are cleared approximately 5 m on either side of the transmission line which runs west and connects with to the Klondike Highway.

## 10.7 Air Photo Review

Aerial photographs were reviewed from 1946, 1971, 1986, 1994, 2004 and a Google Earth image from 2013.

The 1946 aerial photograph indicated the surrounding was undeveloped. The 2001 Deep Creek Community Plan states that the Deep Creek Community originated as a federal forestry campground and recreational area. The original subdivision (lots 1-45) was registered in 1955 (Yukon Government - Community Services Branch, 2001).

Deep Creek Road and a cleared area can be seen west of Deep Creek Road north of the site. A large clearing can also be seen approximately 200 m southeast of the site south of Deep Creek Road.

The Klondike Highway can be seen in the 1986 aerial photograph. A clearing and access road can be seen approximately 200 m northeast of the site which appears to be the location of the old landfill facility. A building can be seen in the center of the large clearing to the southeast of the site. The construction of Deep Creek Road South appears to have started south of the site. Several small buildings can also be seen on lots along Deep Creek Road. An apparent gravel pit or borrow area can be seen approximately 1000 m west of the site on the east side of the Klondike Highway.

A power line that appears to be running in the east west direction can be seen approximately 75 m north of the site in the 1994 aerial photograph. The power line appears to extend west to the Klondike Highway.

In the 2004 aerial photograph, additional building shadows can be seen in the clearing southeast of the site. A clearing can be seen approximately 1300 m northwest of the site which appears to be the location of the Deep Creek landfill facility. The apparent gravel pit or borrow area approximately 1000 m west of the site appears to have increased in size.

It can be seen that there are six smaller buildings in the clearing southeast of the site in addition to the original large building upon review of the 2013 Google Earth image. No other changes were observed.

## 10.8 Zone 1 – 90 Day Travel Time (Sanitary Protection Zone)

A bacteriological or chemical contaminant release in Zone 1 presents a high likelihood of exposure to the users of the community well (DC-2). Based on the aquifer transmissivity and hydraulic gradient, analytical equations were used to calculate the theoretical capture area for a travel time of 90 days. Zone 1 therefore includes a quasi-circular area surrounding DC-2 with a radius of approximately 200 m in the up-gradient direction and 150 m in other directions. Zone 1 does not intersect Deep Creek, based on the average pumping rate 0.35 L/s.

There are currently no known sources of contamination in Zone 1; however, Tetra Tech EBA identified the following potential future hazards to this zone:

- Spills/leaks of petrochemical products or other chemicals from off-road recreational vehicles, vehicles accessing the water fill station, travelling on or completing maintenance on Deep Creek Road south; and
- Spills/ leaks from future development (septic fields, fuel tanks) within Zone 1.

## 10.9 Zone 2 – One Year Travel Time

A contaminant release within Zone 2 represents a medium to high (depending on retardation, natural attenuation) exposure likelihood to the users of DC-2. The one year well capture zone includes a semicircular area surrounding DC-2 between a radius of approximately 150 and 800 m and is bound by Deep Creek to the north. This zone does not extend beyond the groundwater elevation contour that matches the lowest expected drawdown at DC-2 based on the anticipated demand of 0.35 L/s. Tetra Tech EBA identified the following potential hazards to this zone:

- Spills/leaks of petrochemical products and other products from off-road recreational vehicles, vehicles completing maintenance on Deep Creek Road south;
- Spill or leaks from future developments within Zone 2; and
- Spills/leaks of chemical products into ponded recharge areas up-gradient of DC-2.

## 10.10 Zone 3 – Seven Year Travel Time (Ultimate Capture Zone)

A contaminant release within Zone 3 represents medium to low (depending on natural attenuation) exposure likelihood to the users of DC-2. Note that the theoretical capture Zone 3 intersects the northern edge of the Grizzly Valley development. Tetra Tech EBA identified the following potential hazards to this zone:

- Spills/leaks of petrochemical or other chemical products from vehicles traveling on the Klondike highway, vehicles working at the gravel pit on the east side of the Klondike Highway;
- Septic disposal fields, fuel storage and handling in the Grizzly Valley residential development located on the west side of the Klondike Highway;
- Spills/leaks of chemical products into ponded recharge areas upgradient of DC-2;
- Spills of chemical products on secondary road to the south of DC-2, which intersects the Klondike highway at km 223; and
- Future potential risk could include groundwater impacts from future developments or industrial activity such as mining and logging.

## 10.11 Risk Evaluation and Mapping

Estimates of the risk to facility users from each hazard have been developed using the Risk Matrix shown in Figure 5. The risk estimates are based on several factors including:


- Size and magnitude of the hazard (point source or non-point source);
- Location (i.e. distance from the well);
- Groundwater travel time to the well;
- The likelihood of the contaminant directly affecting water at the well; and
- The severity of the hazard to water entering the well.

The above mentioned factors were used to define the categories of exposure likelihood and hazard consequence.

Table 8 identifies “Very Low”, “Low”, “Medium”, or “High” potential values to exposure likelihood and hazard consequence for each well capture zone within travel times previously identified.

Exposure Likelihood		Criteria
Bacteriological Pathogen	Chemical Pathogen	
Very Low	Medium	Groundwater travel time 1 to 7 years (Zone 3)
Low	High	Groundwater travel time - 1 year or less (Zone2)
High	Very High	Groundwater travel time less than 90 days (Zone 1)

The risk matrix (Figure 5) provides the potential risk posed by each hazard within the well capture zone for DC-2. The overall Risk of “Low”, “Medium”, “High” is assigned to each potential hazard identified within the capture zones and is passed on the combined exposure likelihood and hazard consequence for each potential contaminant source. Figure 5 also includes the risk rank results, which are a function of applying the hazard scenario to the risk matrix framework, and provide an overall risk ranking for individual contaminant sources.



**Figure 5: Exposure Likelihood Versus the Hazard Consequence.**

Table 9 represents a summary of risk scenarios evaluated based on exposure and hazard categories identified in Table 8 using the Risk Matrix (Figure 5).

<b>Table 9: Risk Database and Risk Evaluation</b>					
<b>Map ID</b>	<b>Time (Capture Zone)</b>	<b>Hazard Description</b>	<b>Exposure Likelihood</b>	<b>Hazard Consequence</b>	<b>Risk Rank</b>
C1	Zone 1 – less than 90 days	Chemical spills/leaks within Zone 1.	High	High	High
C2	Zone 2 – less than one year	Chemical spills/leaks within Zone 2.	High	High	High
C3	Zone 3 – one to seven years	Chemical spills/leaks within Zone 3	Medium	High	Medium
B1	Zone 1 – less than 90 days	Bacteria, Viruses, Protozoa within Zone 1	High	High	High

A Capture Zone Map showing Zones 1 through 3 is included as Figure 6. The capture zones shown on the Capture Zone Map are colour coded according to the travel time and corresponding exposure likelihood.

The Risk Database represents the current conditions of the well and aquifer and should not be considered as a static item. The Risk Database and Capture Zone Map should be updated as new risks are identified and as known risks are managed to low levels and taken off the database.

## 11.0 STAGE THREE – RISK MANAGEMENT

### 11.1 Risk Management Strategy

The risk management strategy integrates information collected during the capture zone delineation and hazard identification steps and provides workable strategies for preventing, detecting, and responding to wellhead protection risks. The following includes examples of such strategies:

- Endorsing and promoting Best Management Practices (BMPs);
- Providing public and landowner information sessions and training; and
- Implementing Action and Management Strategies provided in Table 10.

The hazard scenarios identified are potential rather than existing threats to DC-2. Therefore, based on the AWPP assessment, the most appropriate risk management for this site will be preventative action and contingency planning in the event that one of the potential hazard scenarios occurs.

In terms of risk communication, the Risk Map can form a concise and convenient basis for communicating information regarding the status of potential threats to all stakeholders including the risk management team, water system operators, community organizations, or municipal councils. Frequent reporting is important to document progress, improve public perception, reduce potential legal issues and possibly reduce insurance costs.

### 11.2 Risk Reduction Plan

A Risk Reduction Plan involves pre-planning actions to respond to acute risks situated within the capture zone. For example, this would include emergency response actions and communication should a contaminant release occur within a well capture zone. A list of risk reduction and elimination strategies is provided in Table 10.

<b>Table 10: Risk Reduction/Elimination Strategies to be Considered</b>				
<b>Map ID</b>	<b>Hazard Description</b>	<b>Risk</b>	<b>Risk Reduction Options to Consider</b>	<b>Risk Elimination Options to Consider</b>
C1,C2, C3, B1	Release or spill from vehicles, fuel storage, septic disposal or future developments within Zones 1, 2 and 3	Medium to High	<ul style="list-style-type: none"> <li>▪ Prevent future development (with the exception of the water treatment plant) within Zones 1 and 2.</li> <li>▪ Ensure proper grading away from the wellhead.</li> <li>▪ Prohibit higher risk (commercial and industrial) development in the capture zone (Zone 1 to 3).</li> <li>▪ Do not have on-site sewage disposal or fuel storage at the water treatment plant.</li> <li>▪ Develop and implement an Emergency Spill Response Plan (ERP).</li> <li>▪ Community engagement and education regarding best</li> <li>▪ Management Practices for fuel storage and septic disposal in Zone 3.</li> </ul>	<ul style="list-style-type: none"> <li>▪ It is difficult to eliminate this risk completely since the risks are based on potential activities and development and the Klondike highway is used for transportation of chemical goods to other Yukon communities.</li> </ul>

### 11.3 Risk Monitoring

A Risk Monitoring Plan involves periodic review, auditing and updating of the Risk Maps and Risk Database. Once an AWPP is in place, continued implementation of the program is essential for it to be worthwhile. The Risk Monitoring Plan would include periodic inspections of the DC-2 wellhead, periodic inspections of the capture zones for new AWPP hazards, working together with the community of Deep Creek to identify and create zoning by-laws and updating the status of risks as risk management actions are implemented. Risk monitoring will allow for the Risk Map to be updated regularly for display or reporting purposes.



## 12.0 CONCLUSIONS AND RECOMMENDATIONS

### 12.1 Conclusions

The following conclusions are based on the information presented in the DC-2 well completion report:

- In January 2014, the test well DC-2 was drilled for YG-IDB in the Deep Creek area to a depth of 122.5 m bgs. The well was completed in a confined bedrock aquifer with a PVC liner and a well screen from 67.7 to 122.5 m bgs;
- The well was constructed in accordance with the Canadian Groundwater Association's Guidelines for Water Well Construction (CGWA 1995) and Yukon Drinking water Regulation, Part 1 – Large Public Drinking Water Systems;
- Pumping test results from the well indicate a bulk aquifer transmissivity in the order of  $7.5 \times 10^{-5} \text{ m}^2/\text{s}$  ( $6.5 \text{ m}^2/\text{day}$ );
- The long-term theoretical sustainable yield of DC-2 is 1.6 L/s (25.4 USgpm); with a recommended short term (less than 48 hr) pumping rate not to exceed 1.8 L/s;
- Tetra Tech EBA identified the well as non-GUDI as the well is completed within a deep confined bedrock aquifer, all upper fractures were sealed off by the 152 mm and 203 mm casings, the well is significantly more than 60 m from the nearest surface water body, and DC-2 sampling results indicate that water quality is dissimilar to surface water obtained from Deep Creek; and
- Laboratory results from the water sample collected on January 21, 2014 show that the water quality of the sample from DC-2 met all GCDWG for the parameters tested, except for iron, hardness, and TDS, which exceeded the aesthetic objective.

The AWPP includes capture zones of varying vulnerability for DC-2 which consists of Zone 1, the sanitary zone (immediately around the wellhead and capture zone within a 90 day travel time), Zone 2 (90 day to one year travel time) and Zone 3 (one year to seven year travel time). Based on the findings of this study, Tetra Tech EBA emphasizes the following conclusions:

- To date there has been no identified contamination in groundwater sampled from DC-2;
- There are currently no known sources of contamination in the well capture zone;
- Any release of contaminants within the identified capture zone would represent a potential risk to the aquifer and water quality of the Deep Creek Water Supply Facility; and,
- The highest risks to DC-2 are from potential spills or releases within the capture zone areas up-gradient of DC-2.

## 12.2 Recommendations

### Well Commissioning, Operation and Maintenance

Proper well commissioning, operation and maintenance are fundamental to ensuring a reliable drinking water source. Recommendations pertinent to the commissioning, operation and maintenance of the DC-2 are presented below:

- If this well is to be developed as a community water supply, we recommend that the submersible pump be installed at a depth of approximately 52.75 m bgs (1.5 m above the upper most water-bearing fracture zone) to maximize drawdown and well performance;
- The pump to be installed in the well should be capable of pumping at 1.8 L/s, overcoming a head of 46 m plus pipe friction losses and possible additional elevation gains to the water treatment plant. Long term pumping rates; however should not exceed the rated safe sustainable yield of the well of 1.6 L/s;
- The well should be “shock chlorinated” (disinfected) prior to commissioning; and,
- Any alterations to the well should be in compliance with the Public Drinking Water Regulations and the Canadian Groundwater Association’s Well Construction Guidelines (CGWA 1995).

### Aquifer and Wellhead Protection

In addition to the recommended risk reduction/ elimination strategies provided in Table 10, Tetra Tech EBA also recommends that YG complete the following:

- Implement contingency planning including emergency response actions and communication. YG should update the existing emergency and spill response plan identifying key personnel responsible to respond in the event of an occurrence or spill when changes in water treatment operator and/or community leadership changes occur;
- Complete regular tracking and monitoring of all well risks in the DC-2 capture zones (either with internal staff resources or outsourced to Tetra Tech EBA);
- Provide protection to the well capture zones by installing signs identifying entrances to the AWPP area;
- Review and update the AWPP on a regular basis. An annual review may be sufficient; however, thought should be given to an “as required” approach; and
- Incorporate this AWPP into the Deep Creek community development plan, and work with the community council to implement a Groundwater Protection Program for the community of Deep Creek and surrounding area. This Groundwater Protection Program should consist of the following:
  - Formal recognition and protection status for identified well protection zones such as those identified in this report;
  - Enforcement of well protection measures;
  - Restrictions on some land use activities within sensitive areas, well protection zones, designated recharge areas and areas of high vulnerability to contamination of the aquifer from surface sources (such as bedrock outcrops and faults); and

- Hydrogeological assessment as a requirement of development for land use activities considered as higher risk, and including groundwater monitoring on and adjacent to specified sites as a condition of development.
- A response action plan and remedial action plans as a condition of development for some specified higher risk land uses.

## 13.0 CLOSURE

We trust this report meets your present requirements. If you have any questions or comments, please contact the undersigned.

Respectfully submitted,  
Tetra Tech EBA Inc.



Prepared by:  
Rob Dickson, E.I.T.  
Junior Engineer - Water Resources  
Environmental Practice  
Direct Line: 867.668-9243  
Rob.Dickson@tetrattech.com



Prepared by:  
Kristen Range, Geol. I. T.  
Junior Hydrogeologist - Water Resources  
Environmental Practice  
Direct Line: 867.668.9233  
Kristen.Range@tetrattech.com



Reviewed by:  
Gareth Earl, E.I.T.  
Junior Engineer - Water Resources  
Environmental Practice  
Direct Line: 867.668.9222  
Gareth.earl@tetrattech.com



Reviewed by:  
Ryan Martin, MEng, P.Eng.  
Discipline Director - Water Resources  
Environmental Practice  
Direct Line: 867.668.9221  
Ryan.Martin@tetrattech.com

/anm/mt

## REFERENCES

- Canadian Groundwater Association (1995) Guidelines for Water Well Construction.
- EBA Engineering Consultants Ltd. (2013), Well Completion Report for Test Well DC-1, Deep Creek, Yukon, April 19, 2013.
- EBA Engineering Consultants Ltd. (2012a), Deep Creek Region Water Supply Feasibility Study. February 6, 2012.
- EBA Engineering Consultants Ltd. (2012b), Grizzly Valley and Deep Creek Test Well Locations (Memo 01). August 8, 2012.
- Federal-Provincial-Territorial Committee on Drinking Water of the Federal-Provincial-Territorial Committee on Health and the Environment (2012) Guidelines for Canadian Drinking Water Quality – Summary Table.
- Fetter, C.W. (2001) Applied Hydrogeology. 4<sup>th</sup> Ed., Prentice-Hall Inc., Upper Saddle River, New Jersey.
- Government of Yukon, Health and Social Services (2007) Guidelines for Part I – Large Public Drinking Water Systems.
- Government of Yukon, Health and Social Services. (2006) Assessment Guideline for Well Water or Groundwater Under the Direct Influence of Surface Water (GUDI).

# TABLES

---

Table 2	Summary of Existing Water Wells and Groundwater Monitoring Wells in the Vicinity of DC-2.
Table 6	Summary of Water Quality Results for Test Well DC-2 and Deep Creek

Table 2: Water Wells in Deep Creek and Grizzly Valley Area

WELL SUMMARY	EBA WELL #	Approx Location (NAD 83, UTM)		DATE DRILLED	DIAMETER	TOTAL DRILLED DEPTH (m)	GENERAL LITHOLOGY	COMPLETED IN	DEPTH TO BEDROCK (m)	Static Water Level (m-bgl)	Estimated Yield (USgpm)	Estimated Yield (L/min)	Estimated Yield (L/sec)	WATER QUALITY <sup>1</sup> AND OTHER COMMENTS
		NORTHING	EASTING											
DC-2	DC-2	6770523	488350	12-Jan-14	6"	122.5	CLAY and SILT over Bedrock	Bedrock	10.5	6.70	23	87	1.4	High TDS and hardness, some iron and manganese.
DC-1	DC-1	6770802	488394	25-Aug-12	6"	101.5	CLAY and SILT over Bedrock	Bedrock	11	3.35	27	102	1.7	High TDS, hardness, iron, manganese, and sulphate.
Bahai Camp, Deep Creek	11	6770665	488606	27-Jun-83	5.5"	93.0	SAND and GRAVEL over TILL over Bedrock	Bedrock	5.2	NK	12 - 15	45 - 57	0.76 - 0.95	No water chemistry data. Anecdotal information suggests the water has a marginal aesthetic quality with poor taste
Bahai Camp, Deep Creek	12	6770665	488606	10-Nov-83	8"	17.4	SAND and SILT over CLAY and SILT over GRAVEL and SAND over Bedrock	Bedrock	16.5	6.7	20	76	1.3	
Bahai Camp, Deep Creek	13	6770665	488606	31-Oct-83	NK	15.8	SAND over CLAY and GRAVEL over GRAVEL and SILT over Bedrock	Bedrock	12.5	Approx 8.8 m	NR	NR	NR	
Lake Laberge Campground	14	6771263	489296	10-Jul-70	5 3/16"	12.2	Bedrock	Bedrock	9.8	NK	2	7.6	0.13	
Brad Cathers, Deep Creek	15	6770994	489152	7-Aug-03	5.5"	42.7	Bedrock	Bedrock	10.7	5.8	15	56.8	0.95	Sample provided by owner on September 12, 2011. All results below drinking water standards.
Don Jacobs, Lake Laberge	16	Unknown	Unknown	8-May-97	NK	50.9	Bedrock	Bedrock	0.0	NK	6	23	0.4	
Roy Sam, Lake Laberge	17	Unknown	Unknown	10-Nov-78	NK	31.7	GRAVEL over CLAY over Bedrock	Bedrock	6.7	NK	1.5	6	0.1	
Ron Pierson, Lake Laberge	18	Unknown	Unknown	1-Jun-77	NK	27.4	CLAY over Bedrock	Bedrock	6.0	9.0	4	15	0.3	
Kate - Campground	21	489197	6771385	NK	NK	NK	NK	NK	NK	NK	NK	NK	NK	Sample obtained by EBA on August 8, 2011. Owner noted well only draws 40 gal before running dry. Fluctuates with lake elevation - GUDI? Sulphate exceeds Drinking Water Guideline - Health Based value (673 mg/L > 500 mg/L)
Joe, Lot 50 Lake Laberge	19	Unknown	Unknown	9-Jul-90	NK	49.7	SILT sand and gravel over Bedrock	Bedrock	4.0	10.4	5	19	0.3	

Notes:

<sup>1</sup>Water chemistry compared against Schedule 3 – Yukon Contaminated Sites Regulation (O.I.C. 2002/171), Drinking Water Standards

**Table 6: Groundwater Analytical Results**

Parameter	Unit	Canadian Drinking Water <sup>1</sup>		DC-2	Deep Creek at Bridge
		MAC	AO/OG	21-Jan-14	22-Jan-14
<b>Physical Tests</b>					
UV Absorbance @ 254nm	Abs/cm-1	NG	NG	0.0120	
True Colour	CU	NG	NG	<5.0	6.0
Electrical Conductivity (EC)	uS/cm	NG	NG	887	324
Hardness as CaCO <sub>3</sub>	µg/L	NG	NG	433,000	170,000
pH	N/A	NG	6.5-8.5	7.69 - 8.08	8.20
Total Suspended Solids (TSS)	µg/L	NG	NG	<3,000	
Total Dissolved Solids (TDS)	µg/L	NG	500,000	<b>634,000</b>	193,000
Transmittance, UV (254 nm)	% T	NG	NG	97.5	
Turbidity	NTU	NG	NG	3.90	1.50
<b>Anions and Nutrients</b>					
Alkalinity (Bicarbonate as CaCO <sub>3</sub> )	µg/L	NG	NG	214,000	
Alkalinity (Carbonate as CaCO <sub>3</sub> )	µg/L	NG	NG	<1,000	
Alkalinity (Hydroxide as CaCO <sub>3</sub> )	µg/L	NG	NG	<1,000	
Alkalinity (Total as CaCO <sub>3</sub> )	µg/L	NG	NG	214,000	151,000
Chloride (Cl)	µg/L	NG	250,000	5,800	<500
Fluoride (F)	µg/L	1,500	NG	<200	
Nitrate and Nitrite (as N)	µg/L	NG	NG	<51	
Nitrate (as N)	µg/L	10,000	NG	<50	73.2
Nitrite (as N)	µg/L	1,000	NG	14	<1.0
Total Kjeldahl Nitrogen (TKN)	µg/L	NG	NG	160	295
Orthophosphate (as P)	µg/L	NG	NG	<1.0	<1.0
Phosphorus (P)	µg/L	NG	NG	<2.0	6.1
Sulphate (SO <sub>4</sub> )	µg/L	500,000	NG	290,000	30,400
<b>Carbon</b>					
Dissolved Organic Carbon (DOC)	µg/L	NG	NG	1,360	
Total Organic Carbon (TOC)	µg/L	NG	NG	1,630	
<b>Hydrocarbons</b>					
Benzene	µg/L	5	NG	<0.50	
Ethylbenzene	µg/L	NG	2.4	<0.50	
Toluene	µg/L	NG	24	<0.50	
Xylene Total	µg/L	NG	300	<0.75	
Styrene	µg/L	NG	NG	<0.50	
EPH C <sub>10</sub> -C <sub>19</sub>	µg/L	NG	NG	<250	
EPH C <sub>19</sub> -C <sub>32</sub>	µg/L	NG	NG	<250	
LEPH	µg/L	NG	NG	<250	
HEPH	µg/L	NG	NG	<250	
Volatile Hydrocarbons (VH <sub>6-10</sub> )	µg/L	NG	NG	<100	
VPH C <sub>6</sub> -C <sub>10</sub>	µg/L	NG	NG	<100	
<b>Total Metals</b>					
Aluminium	µg/L	NG	100	6.2	
Antimony	µg/L	6	NG	0.16	
Arsenic	µg/L	10	NG	0.17	
Barium	µg/L	1,000	NG	13.3	
Beryllium	µg/L	NG	NG	<0.10	
Bismuth	µg/L	NG	NG	<0.50	
Boron	µg/L	5,000	NG	35	
Cadmium	µg/L	5	NG	<0.010	
Calcium	µg/L	NG	NG	79,500	
Chromium (hexavalent)	µg/L	NG	NG	<1.0	
Chromium (III+VI)	µg/L	50	NG	0.24	
Chromium (Trivalent)	µg/L	NG	NG	<5.0	
Cobalt	µg/L	NG	NG	<0.10	
Copper	µg/L	NG	1,000	<0.50	
Iron	µg/L	NG	300	<b>344</b>	
Lead	µg/L	10	NG	<0.050	
Lithium	µg/L	NG	NG	21.4	
Magnesium	µg/L	NG	NG	56,600	
Manganese	µg/L	NG	50	10.5	
Mercury	µg/L	1	NG	<0.010	
Molybdenum	µg/L	NG	NG	3.54	
Nickel	µg/L	NG	NG	<0.50	
Potassium	µg/L	NG	NG	860	
Selenium	µg/L	10	NG	<0.10	
Silicon	µg/L	NG	NG	7,540	
Silver	µg/L	NG	NG	<0.010	
Sodium	µg/L	NG	200,000	37,900	
Strontium	µg/L	NG	NG	6,300	
Sulphur	µg/L	NG	NG	94,700	
Thallium	µg/L	NG	NG	<0.010	
Tin	µg/L	NG	NG	<0.10	
Titanium	µg/L	NG	NG	<10	
Uranium	µg/L	20	NG	0.085	
Vanadium	µg/L	NG	NG	<1.0	
Zinc	µg/L	NG	5,000	<3.0	

**Notes:**

<sup>1</sup> GCDWQ criteria are taken from the "Guidelines for Canadian Drinking Water Quality Summary Table, August 2012"

MAC refers to the Maximum Acceptable Concentration according to the GCDWQ criteria.

AO refers to the Aesthetic Objective according to the GCDWQ criteria.

NG- No guideline

**BOLD** - Exceeds Guideline

*Italic* - Detection limit greater than guideline

N/A - Not applicable



**Table 6: Groundwater Analytical Results**

Parameter	Unit	Canadian Drinking Water <sup>1</sup>		DC-2	Deep Creek at Bridge
		MAC	AO/OG	21-Jan-14	22-Jan-14
<b>Dissolved Metals</b>					
Aluminium	µg/L	NG	100	<1.0	<10
Antimony	µg/L	6	NG	0.13	<0.50
Arsenic	µg/L	10	NG	<0.10	<0.75
Barium	µg/L	1,000	NG	13.1	23
Beryllium	µg/L	NG	NG	<0.10	<100
Bismuth	µg/L	NG	NG	<0.50	<0.20
Boron	µg/L	5,000	NG	33	<100
Cadmium	µg/L	5	NG	<0.010	<0.20
Calcium	µg/L	NG	NG	80,300	47,600
Chromium (hexavalent)	µg/L	NG	NG	<1.0	<2.0
Chromium (III+VI)	µg/L	50	NG	0.18	
Cobalt	µg/L	NG	NG	<0.10	
Copper	µg/L	NG	1,000	<0.20	1.1
Iron	µg/L	NG	300	<b>342</b>	46
Lead	µg/L	10	NG	<0.050	<0.50
Lithium	µg/L	NG	NG	21.7	
Magnesium	µg/L	NG	NG	56,400	12,400
Manganese	µg/L	NG	50	10.2	8.4
Mercury	µg/L	1	NG	<0.010	<0.20
Molybdenum	µg/L	NG	NG	3.29	
Nickel	µg/L	NG	NG	<0.50	
Phosphorus	µg/L	NG	NG	<50	
Potassium	µg/L	NG	NG	970	920
Selenium	µg/L	10	NG	<0.10	<1.0
Silicon	µg/L	NG	NG	7,460	
Silver	µg/L	NG	NG	<0.010	
Sodium	µg/L	NG	200,000	37,300	4,500
Strontium	µg/L	NG	NG	6,270	
Sulphur	µg/L	NG	NG	90,000	
Thallium	µg/L	NG	NG	<0.010	
Tin	µg/L	NG	NG	<0.10	
Titanium	µg/L	NG	NG	<10	
Uranium	µg/L	20	NG	0.081	0.60
Vanadium	µg/L	NG	NG	<1.0	
Zinc	mg/L	NG	5,000	<1.0	<50
<b>Polycyclic Aromatic Hydrocarbons</b>					
Acenaphthene	µg/L	NG	NG	<0.050	
Acenaphthylene	µg/L	NG	NG	<0.050	
Acridine	µg/L	NG	NG	<0.050	
Anthracene	µg/L	NG	NG	<0.050	
Benz(a)anthracene	µg/L	NG	NG	<0.050	
Benzo(a) pyrene	µg/L	0.01	NG	<0.010	
Benzo(b)fluoranthene	µg/L	NG	NG	<0.050	
Benzo(g,h,i)perylene	µg/L	NG	NG	<0.050	
Benzo(k)fluoranthene	µg/L	NG	NG	<0.050	
Chrysene	µg/L	NG	NG	<0.050	
Dibenz(a,h)anthracene	µg/L	NG	NG	<0.050	
Fluoranthene	µg/L	NG	NG	<0.050	
Fluorene	µg/L	NG	NG	<0.050	
Indeno(1,2,3-c,d)pyrene	µg/L	NG	NG	<0.050	
Naphthalene	µg/L	NG	NG	<0.050	
Phenanthrene	µg/L	NG	NG	<0.050	
Pyrene	µg/L	NG	NG	<0.050	
Quinoline	µg/L	NG	NG	<0.050	
MTBE	µg/L	NG	15	<0.50	
<b>Trihalomethane Formation Potential</b>					
Bromodichloromethane	mg/L	NG	NG	0.004	
Bromoform	mg/L	NG	NG	<0.001	
Chloroform	mg/L	NG	NG	0.017	
Dibromochloromethane	mg/L	NG	NG	0.002	
Total Trihalomethanes	mg/L	0.1	NG	0.023	

**Notes:**

<sup>1</sup> GCDWQ criteria are taken from the "Guidelines for Canadian Drinking Water Quality Summary Table, August 2012"

MAC refers to the Maximum Acceptable Concentration according to the GCDWQ criteria.

AO refers to the Aesthetic Objective according to the GCDWQ criteria.

NG- No guideline

Blank - Not analyzed

**BOLD** - Exceeds Guideline

*Italic* - Detection limit greater than guideline

N/A - Not applicable

# FIGURES

---


- Figure 1 Site Location Plan
- Figure 2 Existing Site Conditions
- Figure 3 Observed Drawdown During Pumping Tests
- Figure 4 Extrapolation of Drawdown During Constant Rate Pumping Test to 100 Days
- Figure 6 Local Topography and Aquifer Capture Zones





NOTE : CONTOUR DATA WAS RECEIVED FROM CANVEC 1:50 000 MAPSHEET DATABASE, PROVIDED BY NATIONAL RESOURCES CANADA WEBSITE

- LEGEND:
- MONITORING WELL LOCATION
  - WATER SUPPLY WELL
  - INFERRED GROUNDWATER FLOW DIRECTION
  - 640 - GROUND ELEVATION CONTOUR MAMSL (JULY 2013)



CLIENT

TETRA TECH EBA

HYDROGEOLOGICAL SERVICES DEEP CREEK, YUKON			
SITE LOCATION PLAN			
PROJECT NO. ENVH2003020-01	DWN CB	CKD GJE	REV 0
OFFICE EBA-WHSE	DATE February 6, 2014		

Figure 1






Q:\Whitehorse\Data\201drawings\Deep Creek\ENVH2003020-01\ENVH2003020-01 Fig.2\_R0.dwg [FIGURE 2] February 17, 2014 - 4:23:08 pm (BY: BUCHAN, CAMERON)

**LEGEND**

- TEST WELL LOCATION
- TREELINE



CLIENT





**HYDROGEOLOGICAL SERVICES  
DEEP CREEK, YUKON**

**EXISTING SITE CONDITIONS**

PROJECT NO. ENVH2003020-01	DWN CB	CKD GJE	REV 0
OFFICE EBA-WHSE	DATE February 6, 2014		

**Figure 2**



**LEGEND**

- ◆ DC-2

**NOTES**

**STATUS**  
ISSUED FOR USE

**CLIENT**




**DC-2 WELL COMPLETION AND AWPP**

**Observed Drawdown During Pumping Tests**

<b>PROJECT NO.</b> ENVH2O03020-01	<b>DWN</b> KR	<b>CKD</b> GE	<b>APVD</b> RM	<b>REV</b> 0
<b>OFFICE</b> EBA-WHSE	<b>DATE</b> January 28, 2013			

**Figure 3**



**LEGEND**

- ◆ Drawdown in pumping well during constant rate pumping test
- Extrapolation of drawdown to 100 days

**NOTES**

**STATUS**  
ISSUED FOR USE

**CLIENT**



**DC-2 WELL COMPLETION AND AWPP REPORT**


**Extrapolation of Drawdown During Constant Rate Pumping Test to 100 Days**

<b>PROJECT NO.</b> ENVH203020-01	<b>DWN</b> KR	<b>CKD</b> GE	<b>APVD</b> RM	<b>REV</b> 0
<b>OFFICE</b> EBA-WHSE	<b>DATE</b> January 28, 2014			

**Figure 4**

EBA-TL\_Title\_Block\_8.5x11\_Landscape.cdr





**LEGEND**

- Well
- Gravel Pit
- Road
- Transmission Line
- Contour (40 m)
- Watercourse
- Waterbody
- Wetland

- Aquifer Capture Zone**
- Zone 1 (0 to 90 Days)
  - Zone 2 (90 Days to 1 Year)
  - Zone 3 (1 to 7 Years)

**NOTES**

- 1. Potential Hazards**
- Zone 1:** Spills and leaks of petrochemical and other chemicals from off-road recreational and vehicles travelling on Deep Creek Road South.
  - Zone 2:** Spills and leaks of chemical products into ponded recharge areas upgradient of DC-2.
  - Zone 3:** Spills and leaks of petrochemical and other chemicals from vehicles or temporary tanks at the gravel pit on the east side of the Klondike Highway or from vehicles travelling on highway and secondary roads within the capture zone (2.8 km along the Klondike Highway, 3 km along the service road in the Grizzly Valley subdivision, and a 1 km section of the road that intersects the Klondike Highway at km 223).
- 2.** Base data source: CanVec 1:50,000; Google Earth Pro (April 2013).

**DEEP CREEK HYDROGEOLOGICAL SERVICES**

**Local Topography and Aquifer Capture Zones**

<b>PROJECTION</b> UTM Zone 8	<b>DATUM</b> NAD83	<b>CLIENT</b> <b>Government of Yukon</b>
Scale: 1:40,000 500 250 0 500 Metres		
<b>FILE NO.</b> H2O03020-01_Figure06_Topo_11x17.mxd		
<b>PROJECT NO.</b> ENVH2O03020-01	<b>DWN</b> MEZ	<b>CKD</b> SL
<b>OFFICE</b> Tt EBA-VANC	<b>APVD</b> RD	<b>REV</b> 0
<b>DATE</b> March 3, 2014		<b>Figure 6</b>

**STATUS**  
ISSUED FOR USE

Q:\Vancouver\GIS\ENVIRONMENTAL\H2O\H2O03020-01\Maps\H2O03020-01\_Figure06\_Topo\_11x17.mxd modified 3/3/2014 by stephanie.leusink



# APPENDIX A

## TETRA TECH EBA'S GENERAL CONDITIONS

---



---

# GENERAL CONDITIONS

## GEO-ENVIRONMENTAL REPORT

---

This report incorporates and is subject to these "General Conditions".

---

### 1.1 USE OF REPORT AND OWNERSHIP

This report pertains to a specific site, a specific development, and a specific scope of work. It is not applicable to any other sites, nor should it be relied upon for types of development other than those to which it refers. Any variation from the site or proposed development would necessitate a supplementary investigation and assessment.

This report and the assessments and recommendations contained in it are intended for the sole use of TETRA TECH's client. TETRA TECH does not accept any responsibility for the accuracy of any of the data, the analysis or the recommendations contained or referenced in the report when the report is used or relied upon by any party other than TETRA TECH's Client unless otherwise authorized in writing by TETRA TECH. Any unauthorized use of the report is at the sole risk of the user.

This report is subject to copyright and shall not be reproduced either wholly or in part without the prior, written permission of TETRA TECH. Additional copies of the report, if required, may be obtained upon request.

### 1.2 ALTERNATE REPORT FORMAT

Where TETRA TECH submits both electronic file and hard copy versions of reports, drawings and other project-related documents and deliverables (collectively termed TETRA TECH's instruments of professional service); only the signed and/or sealed versions shall be considered final and legally binding. The original signed and/or sealed version archived by TETRA TECH shall be deemed to be the original for the Project.

Both electronic file and hard copy versions of TETRA TECH's instruments of professional service shall not, under any circumstances, no matter who owns or uses them, be altered by any party except TETRA TECH. The Client warrants that TETRA TECH's instruments of professional service will be used only and exactly as submitted by TETRA TECH.

Electronic files submitted by TETRA TECH have been prepared and submitted using specific software and hardware systems. TETRA TECH makes no representation about the compatibility of these files with the Client's current or future software and hardware systems.

### 1.3 NOTIFICATION OF AUTHORITIES

In certain instances, the discovery of hazardous substances or conditions and materials may require that regulatory agencies and other persons be informed and the client agrees that notification to such bodies or persons as required may be done by TETRA TECH in its reasonably exercised discretion.

### 1.4 INFORMATION PROVIDED TO TETRA TECH BY OTHERS


During the performance of the work and the preparation of the report, TETRA TECH may rely on information provided by persons other than the Client. While TETRA TECH endeavours to verify the accuracy of such information when instructed to do so by the Client, TETRA TECH accepts no responsibility for the accuracy or the reliability of such information which may affect the report.


# APPENDIX B

## DC-2 WELL LOG

---


DC-2 WELL COMPLETION AND AWPP	YUKON GOVERNMENT	PROJECT NO. - BOREHOLE NO.
	DRILL: AIR ROTARY	ENVH2003020-01-DC-2
DEEP CREEK, YUKON	6770522.59N; 488349.79E; Zone 8	ELEVATION: 651.06 m
SAMPLE TYPE	<input type="checkbox"/> DISTURBED <input type="checkbox"/> NO RECOVERY <input type="checkbox"/> SPT <input type="checkbox"/> A-CASING <input type="checkbox"/> SHELBY TUBE <input type="checkbox"/> CORE	
BACKFILL TYPE	<input type="checkbox"/> BENTONITE <input type="checkbox"/> PEA GRAVEL <input type="checkbox"/> SLOUGH <input type="checkbox"/> GROUT <input type="checkbox"/> DRILL CUTTINGS <input type="checkbox"/> SAND	



	LOGGED BY: KR	COMPLETION DEPTH: 122.53 m
	REVIEWED BY: GE	COMPLETE: 14/01/11
	DRAWING NO:	Page 1 of 3


DC-2 WELL COMPLETION AND AWPP	YUKON GOVERNMENT	PROJECT NO. - BOREHOLE NO.
	DRILL: AIR ROTARY	ENVH2003020-01-DC-2
DEEP CREEK, YUKON	6770522.59N; 488349.79E; Zone 8	ELEVATION: 651.06 m

SAMPLE TYPE	<input type="checkbox"/> DISTURBED	<input type="checkbox"/> NO RECOVERY	<input type="checkbox"/> SPT	<input type="checkbox"/> A-CASING	<input type="checkbox"/> SHELBY TUBE	<input type="checkbox"/> CORE
BACKFILL TYPE	<input type="checkbox"/> BENTONITE	<input type="checkbox"/> PEA GRAVEL	<input type="checkbox"/> SLOUGH	<input type="checkbox"/> GROUT	<input type="checkbox"/> DRILL CUTTINGS	<input type="checkbox"/> SAND



	LOGGED BY: KR	COMPLETION DEPTH: 122.53 m
	REVIEWED BY: GE	COMPLETE: 14/01/11
	DRAWING NO:	Page 2 of 3

DC-2 WELL COMPLETION AND AWPP	YUKON GOVERNMENT	PROJECT NO. - BOREHOLE NO.
	DRILL: AIR ROTARY	ENVH2003020-01-DC-2
DEEP CREEK, YUKON	6770522.59N; 488349.79E; Zone 8	ELEVATION: 651.06 m
SAMPLE TYPE	<input type="checkbox"/> DISTURBED <input type="checkbox"/> NO RECOVERY <input type="checkbox"/> SPT <input type="checkbox"/> A-CASING <input type="checkbox"/> SHELBY TUBE <input type="checkbox"/> CORE	
BACKFILL TYPE	<input type="checkbox"/> BENTONITE <input type="checkbox"/> PEA GRAVEL <input type="checkbox"/> SLOUGH <input type="checkbox"/> GROUT <input type="checkbox"/> DRILL CUTTINGS <input type="checkbox"/> SAND	



LOGGED BY: KR	COMPLETION DEPTH: 122.53 m
REVIEWED BY: GE	COMPLETE: 14/01/11
DRAWING NO:	Page 3 of 3

# APPENDIX C

## DRILLER'S WELL LOG

---





# APPENDIX D

## STEP AND CONSTANT RATE PUMPING TEST MANUAL DATA AND INTERPRETATION

---



## STEP-DRAWDOWN PUMPING TEST DATA

<b>EBA Project Number:</b>	ENVH2O03020-01	<b>Project Location:</b>	Deep Creek
<b>Well Name:</b>	DC-2	<b>Pump Intake Depth (m):</b>	60 m
<b>Static Water Level* (m):</b>	7.585 m	<b>Screen Interval (X to Y depth):</b>	67 – 121 m
<b>Ref. Point Description:</b>	Top of 6" PVC	<b>Screen Slot Size ("):</b>	.020"
<b>Ref. Point Stick-Up (m):</b>	0.89 m	<b>Safe Available Drawdown** (m):</b>	55.0 m
<b>Well Diameter (mm):</b>	152.4 mm	<b>Screen Diameter (mm):</b>	127 mm
<b>Total Well Depth (m):</b>	121.03 m	<b>Observer's Name:</b>	Kristen Range

\*below reference point

\*\*equal to (pump depth m – SWL m) x 0.7

Date	Time	Elapsed Time (min)	Depth to Water (m)	Drawdown (m)	Meter Reading <sup>3</sup>	Flow Rate (IGPM)	Flow Rate (L/s)	Specific Capacity (L/s/m)	Comments
01/18/14	4:57:00	0	7.585	0	7.23	6.02	0.38		
	4:57:30	0.5	9.09	1.504	7.23	6.02	0.38	0.25	
	4:58:00	1	9.13	1.544	7.23	6.02	0.38	0.25	
	4:58:30	1.5	9.17	1.584	7.23	6.02	0.38	0.24	
	4:59:00	2	9.22	1.634	7.23	6.02	0.38	0.23	
	4:59:30	2.5	9.27	1.684	7.23	6.02	0.38	0.23	
	5:00:00	3	9.32	1.734	7.23	6.02	0.38	0.22	
	5:00:30	3.5	9.37	1.784	7.23	6.02	0.38	0.21	
	5:01:00	4	9.42	1.834	7.23	6.02	0.38	0.21	
	5:01:30	4.5	9.455	1.869	7.23	6.02	0.38	0.20	
	5:02:00	5	9.475	1.889	7.23	6.02	0.38	0.20	
	5:03:00	6	9.55	1.964	7.23	6.02	0.38	0.19	
	5:04:00	7	9.59	2.004	7.23	6.02	0.38	0.19	
	5:05:00	8	9.63	2.044	7.23	6.02	0.38	0.19	
	5:06:00	9	9.665	2.079	7.23	6.02	0.38	0.18	
	5:07:00	10	9.698	2.112	7.23	6.02	0.38	0.18	
	5:09:00	12	9.765	2.179	7.23	6.02	0.38	0.17	
	5:11:00	14	9.805	2.219	7.23	6.02	0.38	0.17	
	5:13:00	16	9.84	2.254	7.23	6.02	0.38	0.17	
	5:15:00	18	9.89	2.304	7.23	6.02	0.38	0.16	
	5:17:00	20	9.939	2.353	7.23	6.02	0.38	0.16	
	5:22:00	25	10.036	2.45	7.23	6.02	0.38	0.16	
	5:27:00	30	10.113	2.527	7.23	6.02	0.38	0.15	
	5:32:00	35	10.176	2.59	7.23	6.02	0.38	0.15	
	5:37:00	40	10.228	2.642	7.23	6.02	0.38	0.14	

	5:42:00	45	10.274	2.688	7.23	6.02	0.38	0.14	
	5:47:00	50	10.32	2.734	7.23	6.02	0.38	0.14	
	5:52:00	55	10.35	2.764	7.23	6.02	0.38	0.14	
	5:57:00	60	10.39	2.804	7.23	6.02	0.38	0.14	
	5:57:30	60.5	10.9	3.314	14.26	11.89	0.75	0.23	
	5:58:00	61	10.295	2.709	14.26	11.89	0.75	0.28	
	5:58:30	61.5	11.545	3.959	14.26	11.89	0.75	0.19	
	5:59:00	62	11.74	4.154	14.26	11.89	0.75	0.18	
	5:59:30	62.5	11.925	4.339	14.26	11.89	0.75	0.17	
	6:00:00	63	12.07	4.484	14.26	11.89	0.75	0.17	
	6:00:30	63.5	12.215	4.629	14.26	11.89	0.75	0.16	
	6:01:00	64	12.305	4.719	14.26	11.89	0.75	0.16	
	6:01:30	64.5	12.38	4.794	14.26	11.89	0.75	0.16	
	6:02:00	65	12.47	4.884	14.26	11.89	0.75	0.15	
	6:03:00	66	12.59	5.004	14.26	11.89	0.75	0.15	
	6:04:00	67	12.69	5.104	14.26	11.89	0.75	0.15	
	6:05:00	68	12.76	5.174	14.26	11.89	0.75	0.14	
	6:06:00	69	12.83	5.244	14.26	11.89	0.75	0.14	
	6:07:00	70	12.888	5.302	14.26	11.89	0.75	0.14	
	6:09:00	72	12.98	5.394	14.26	11.89	0.75	0.14	
	6:11:00	74	13.055	5.469	14.26	11.89	0.75	0.14	
	6:15:00	78	13.18	5.594	14.26	11.89	0.75	0.13	
	6:17:00	80	13.23	5.644	14.26	11.89	0.75	0.13	
	6:22:00	85	13.342	5.756	14.26	11.89	0.75	0.13	
	6:27:00	90	13.425	5.839	14.26	11.89	0.75	0.13	
	6:32:00	95	13.497	5.911	14.26	11.89	0.75	0.13	
	6:37:00	100	13.559	5.973	14.26	11.89	0.75	0.13	
	6:43:00	106	13.63	6.044	14.26	11.89	0.75	0.12	
	6:47:00	110	13.675	6.089	14.26	11.89	0.75	0.12	
	6:52:00	115	13.738	6.152	14.26	11.89	0.75	0.12	
	6:57:00	120	13.778	6.192	20.35	16.96	1.07	0.17	
	6:57:30	120.5	14.28	6.694	20.35	16.96	1.07	0.16	
	6:58:00	121	14.72	7.134	20.35	16.96	1.07	0.15	
	6:58:30	121.5	15.08	7.494	20.35	16.96	1.07	0.14	
	6:59:00	122	15.38	7.794	20.35	16.96	1.07	0.14	
	6:59:30	122.5	15.65	8.064	20.35	16.96	1.07	0.13	
	7:00:00	123	15.9	8.314	20.35	16.96	1.07	0.13	
	7:01:00	124	16.255	8.669	20.35	16.96	1.07	0.12	

	7:01:30	124.5	16.41	8.824	20.35	16.96	1.07	0.12	
	7:02:00	125	16.54	8.954	20.35	16.96	1.07	0.12	
	7:03:00	126	16.778	9.192	20.35	16.96	1.07	0.12	
	7:05:00	128	17.125	9.539	20.35	16.96	1.07	0.11	
	7:06:00	129	17.26	9.674	20.35	16.96	1.07	0.11	
	7:07:00	130	17.43	9.844	20.35	16.96	1.07	0.11	
	7:09:00	132	17.605	10.019	20.35	16.96	1.07	0.11	
	7:11:00	134	17.72	10.134	20.35	16.96	1.07	0.11	
	7:13:00	136	17.85	10.264	20.35	16.96	1.07	0.10	
	7:15:00	138	17.96	10.374	20.35	16.96	1.07	0.10	
	7:17:00	140	18.058	10.472	20.35	16.96	1.07	0.10	
	7:22:00	145	18.23	10.644	20.35	16.96	1.07	0.10	
	7:29:30	152.5	18.44	10.854	20.35	16.96	1.07	0.10	
	7:32:00	155	18.502	10.916	20.35	16.96	1.07	0.10	
	7:37:00	160	18.595	11.009	20.35	16.96	1.07	0.10	
	7:42:00	165	18.689	11.103	20.35	16.96	1.07	0.10	
	7:47:00	170	18.777	11.191	20.35	16.96	1.07	0.10	
	7:52:00	175	18.863	11.277	20.35	16.96	1.07	0.09	
	7:56:30	178.5	18.91	11.324	20.35	16.96	1.07	0.09	
	7:57:00	180	18.93	11.344	30.62	25.52	1.61	0.14	
	7:57:30	180.5	19.42	11.834	30.62	25.52	1.61	0.14	
	7:58:00	181	19.97	12.384	30.62	25.52	1.61	0.13	
	7:58:30	181.5	20.63	13.044	30.62	25.52	1.61	0.12	
	7:59:00	182	20.99	13.404	30.62	25.52	1.61	0.12	
	7:59:30	182.5	21.39	13.804	30.62	25.52	1.61	0.12	
	8:00:00	183	21.61	14.024	30.62	25.52	1.61	0.11	
	8:00:30	183.5	22.17	14.584	30.62	25.52	1.61	0.11	
	8:01:00	184	22.535	14.949	30.62	25.52	1.61	0.11	
	8:01:30	184.5	22.84	15.254	30.62	25.52	1.61	0.11	
	8:02:00	185	23.15	15.564	30.62	25.52	1.61	0.10	
	8:03:00	186	23.64	16.054	30.62	25.52	1.61	0.10	
	8:04:00	187	24.075	16.489	30.62	25.52	1.61	0.10	
	8:05:00	188	24.496	16.91	30.62	25.52	1.61	0.10	
	8:06:00	189	24.87	17.284	30.62	25.52	1.61	0.09	
	8:07:00	190	25.19	17.604	30.62	25.52	1.61	0.09	
	8:09:00	192	25.7	18.114	30.62	25.52	1.61	0.09	
	8:11:00	194	26.183	18.597	30.62	25.52	1.61	0.09	
	8:13:00	196	26.405	18.819	30.62	25.52	1.61	0.09	

	8:15:00	198	26.64	19.054	30.62	25.52	1.61	0.08	
	8:17:00	200	26.828	19.242	30.62	25.52	1.61	0.08	
	8:22:00	205	27.165	19.579	30.62	25.52	1.61	0.08	
	8:27:00	210	27.77	20.184	30.62	25.52	1.61	0.08	
	8:32:00	215	28.14	20.554	30.62	25.52	1.61	0.08	
	8:37:00	220	28.315	20.729	30.62	25.52	1.61	0.08	
	8:42:00	225	28.505	20.919	30.62	25.52	1.61	0.08	
	8:47:00	230	28.68	21.094	30.62	25.52	1.61	0.08	
	8:57:00	240	28.915	21.329	30.62	25.52	1.61	0.08	
	9:07:00	250	29.11	21.524	30.62	25.52	1.61	0.07	Pump Off
	9:07:43	250.75	29.125	21.539					Recovery
	9:08:05	251	27	19.414					
	9:08:31	251.5	25	17.414					
	9:08:46	251.75	24	16.414					
	9:09:03	252	23	15.414					
	9:09:19	252.3	22	14.414					
	9:09:36	252.7	21	13.414					
	9:09:58	253	20	12.414					
	9:10:24	253.5	19	11.414					
	9:10:51	253.9	18	10.414					
	9:11:20	254.3	17	9.414					
	9:11:54	254.9	16	8.414					
	9:12:32	255.5	15	7.414					
	9:13:30	256.5	14	6.414					
	9:14:52	257.9	13	5.414					
	9:19:03	262	11.75	4.164					
	9:27:19	270.5	10.95	3.364					
	9:34:30	277.5	10.6	3.014					
	9:43:30	286.5	10.211	2.625					
	9:48:30	291.5	10.14	2.554					
01/19/14	11:36:00	1119	8.02	0.434					

Notes:

- 1) Depth to Water below reference point (e.g., top of sounding tube).
- 2) "-" indicates no data or not applicable.
- 3) May be from a flow totalizer, instantaneous flow meter or other method of flow rate monitoring. Note in comment column.

## CONSTANT RATE PUMPING TEST DATA

<b>EBA Project Number:</b>	ENVH2O03020-01	<b>Project Location:</b>	Deep Creek
<b>Well Name:</b>	DC-2	<b>Pump Intake Depth (m):</b>	60 m
<b>Static Water Level* (m):</b>	8.02 m	<b>Screen Interval (X to Y depth):</b>	67 – 121 m
<b>Ref. Point Description:</b>	Top of 6" PVC	<b>Screen Slot Size ("):</b>	.020"
<b>Ref. Point Stick-Up (m):</b>	0.89 m	<b>Safe Available Drawdown** (m):</b>	55.0 m
<b>Well Diameter (mm):</b>	152.4 mm	<b>Screen Diameter (mm):</b>	127 mm
<b>Total Well Depth (m):</b>	121.03 m	<b>Observer's Name:</b>	Kristen Range

\*below reference point      \*\*equal to (pump depth m – SWL m) x 0.7

Date	Time	Elapsed Time (min)	Depth to Water (m)	Drawdown (m)	Meter Reading <sup>3</sup>	Flow Rate (IGPM)	Flow Rate (L/s)	pH	EC	Temp	Comments
01/19/14	12:00	0	8.02	0							
	12:00	0.5	10.52	2.50							
	12:01	1	12.64	4.62							
	12:01	1.5	13.43	5.41							
	12:02	2	14.66	6.64							
	12:02	2.5	15.64	7.62							
	12:03	3	16.48	8.46							
	12:03	3.5	17.25	9.23							
	12:04	4	17.93	9.91							
	12:04	4.5	18.5	10.48							
	12:05	5	19.04	11.02							
	12:06	6	19.96	11.94							
	12:07	7	20.74	12.72							
	12:08	8	21.38	13.36							
	12:09	9	21.9	13.88							
	12:10	10.5	22.63	14.61							
	12:12	12	23.21	15.19							
	12:15	15	24.03	16.01							
	12:16	16	24.23	16.21							
	12:18	18	24.625	16.605							
	12:20	20	25.095	17.075							
	12:25	25	25.8	17.78							
	12:30	30	26.215	18.195							
	12:36	36.5	26.585	18.565							
	12:41	41	26.78	18.76							
	12:48	48	27.035	19.015							
	12:50	50	27.105	19.085							
	12:56	56	27.325	19.305							
	13:00	60	27.45	19.43							

Date	Time	Elapsed Time (min)	Depth to Water (m)	Drawdown (m)	Meter Reading <sup>3</sup>	Flow Rate (IGPM)	Flow Rate (L/s)	pH	EC	Temp	Comments
	13:03	73	27.78	19.76							
	13:20	80	27.92	19.9	21.6	21.6	1.4	8.01	523	2.9	
	13:32	92	28.135	20.115							
	13:40	100	28.279	20.259							
	13:50	110	28.652	20.632							
	14:00	120	28.846	20.826							
	14:30	150	29.339	21.319							
	15:00	180	29.6	21.58							
	15:30	210	29.892	21.872							
	16:00	240	30.129	22.109							
	16:30	270	30.341	22.321				7.62	528	5.2	
	17:00	300	30.526	22.506							
	17:30	330	30.69	22.67							
	18:00	360	30.828	22.808	23.8	23.8	1.5	7.72	520	2.9	
	19:00	420	31.051	23.031							
	20:00	480	31.21	23.19							
	21:00	540	31.309	23.289							
	22:00	600	31.741	23.721				7.72	518	2.9	
	23:00	660	31.76	23.74							
01/20/14	0:00	720	31.893	23.873							
	1:00	780	31.945	23.925							
	2:00	840	32.065	24.045							
	3:00	900	32.11	24.09							
	4:00	960	32.17	24.15							
	5:00	1020	32.235	24.215							
	6:00	1080	32.245	24.225							
	7:00	1140	32.251	24.231	23.8	23.8	1.5	7.71	517	2.8	
	8:00	1200	32.311	24.291							
	9:00	1260	32.389	24.369							
	10:00	1320	32.398	24.378							
	11:00	1380	32.441	24.421							
	12:00	1440	32.487	24.467							
	13:00	1500	32.514	24.494							
	14:00	1560	32.531	24.511	22.1	22.1	1.4	7.75	516	2.8	
	15:00	1620	32.548	24.528							
	16:00	1680	32.793	24.773							
	17:00	1740	32.821	24.801							
	18:00	1800	32.834	24.814							
	19:00	1860	32.843	24.823				7.7	509	2.7	

Date	Time	Elapsed Time (min)	Depth to Water (m)	Drawdown (m)	Meter Reading <sup>3</sup>	Flow Rate (IGPM)	Flow Rate (L/s)	pH	EC	Temp	Comments
	20:00	1920	32.871	24.851							
	21:00	1980	32.886	24.866							
	22:00	2040	32.941	24.921							
	23:00	2100	32.966	24.946							
01/21/14	0:00	2160	32.973	24.953							
	1:00	2220	32.974	24.954							
	2:00	2280	32.991	24.971							
	3:00	2340	33.01	24.99							
	4:00	2400	32.3023	24.2823	22.3	22.3	1.4				
	5:00	2460	33.022	25.002							
	6:00	2520	32.994	24.974							
	7:00	2580	32.998	24.978							
	8:00	2640	33.037	25.017	23.0	23.0	1.5	7.78	518	2.7	
	9:00	2700	33.043	25.023							
	10:00	2760	33.056	25.036							
	11:00	2820	33.078	25.058							
	12:00	2880	33.075	25.055				8.03	518	2.9	Pump Off
	12:44	2924	33.1	25.08							Recovery
	12:44	2924	30	21.98							
	12:44	2924	29	20.98							
	12:45	2925	28	19.98							
	12:45	2925	27	18.98							
	12:45	2925	26	17.98							
	12:46	2926	25	16.98							
	12:46	2926	24	15.98							
	12:46	2926	23	14.98							
	12:47	2927	22	13.98							
	12:47	2927	21	12.98							
	12:48	2928	20	11.98							
	12:48	2928	19	10.98							
	12:49	2929	18	9.98							
	12:50	2930	17	8.98							
	12:52	2932	16	7.98							
	12:55	2935	15	6.98							
	12:59	2939	14.5	6.48							
	13:06	2946	14	5.98							
	13:17	2957	13.5	5.48							
	13:33	2973	13	4.98							
	13:55	2995	12.5	4.48							

Date	Time	Elapsed Time (min)	Depth to Water (m)	Drawdown (m)	Meter Reading <sup>3</sup>	Flow Rate (IGPM)	Flow Rate (L/s)	pH	EC	Temp	Comments
	14:00	3000	14.431	6.411							
01/22/14	9:56	4196	8.655	0.635							
Notes: 1) Depth to Water below reference point (e.g., top of sounding tube). 2) "-" indicates no data or not applicable. 3) May be from a flow totalizer, instantaneous flow meter or other method of flow rate monitoring. Note in comment column.											





**Tetra Tech EBA**  
**61 Wasson Place**  
**Whitehorse, YT Y1A 0H7**


**Pumping Test Analysis Report**

Project: DC-2 Well Completion and AWPP

Number: ENVH2O03020-01

Client: Government of Yukon

Location: DC-2	Pumping Test: DC-2 Constant Rate Pumping Test	Pumping Well: DC-2
Test Conducted by: RD/KRR		Test Date: 1/22/2014
Analysis Performed by: KRR	Cooper & Jacob I	Analysis Date: 1/24/2014
Aquifer Thickness: 68.00 m	Discharge: variable, average rate 23 [U.S. gal/min]	



Calculation using COOPER & JACOB

Observation Well	Transmissivity [m <sup>2</sup> /s]	Hydraulic Conductivity [m/s]	Storage coefficient	Radial Distance to PW [m]
DC-2	$7.00 \times 10^{-5}$	$1.03 \times 10^{-6}$	$8.72 \times 10^{-4}$	



**Tetra Tech EBA**  
 61 Wasson Place  
 Whitehorse, YT Y1A 0H7


**Pumping Test Analysis Report**

Project: DC-2 Well Completion and AWPP

Number: ENVH2O03020-01

Client: Government of Yukon

Location: DC-2	Pumping Test: DC-2 Constant Rate Pumping Test	Pumping Well: DC-2
Test Conducted by: RD/KRR		Test Date: 1/22/2014
Analysis Performed by: KRR	Theis Recovery	Analysis Date: 1/22/2014
Aquifer Thickness: 68.00 m	Discharge: variable, average rate 23 [U.S. gal/min]	



Calculation using THEIS & JACOB

Observation Well	Transmissivity [m <sup>2</sup> /s]	Hydraulic Conductivity [m/s]	Radial Distance to PW [m]
DC-2	$8.00 \times 10^{-5}$	$1.18 \times 10^{-6}$	

# APPENDIX E

## DC-2 LABORATORY RESULTS

---



Tetra Tech EBA Inc.  
ATTN: Gareth Earl  
61 Wasson Place  
Whitehorse YT Y1A 0H7

Date Received: 21-JAN-14  
Report Date: 30-JAN-14 10:51 (MT)  
Version: FINAL

Client Phone: 867-668-9222

## Certificate of Analysis

**Lab Work Order #:** L1414070  
**Project P.O. #:** NOT SUBMITTED  
**Job Reference:**  
**C of C Numbers:** 10-267432  
**Legal Site Desc:**

---

Brent Mack  
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 8081 Lougheed Hwy, Suite 100, Burnaby, BC V5A 1W9 Canada | Phone: +1 604 253 4188 | Fax: +1 604 253 6700  
ALS CANADA LTD Part of the ALS Group A Campbell Brothers Limited Company

# ALS ENVIRONMENTAL ANALYTICAL REPORT

	Sample ID Description Sampled Date Sampled Time Client ID				
	L1414070-1 Grab 21-JAN-13 12:15 DC-2				
Grouping	Analyte				
<b>WATER</b>					
<b>Physical Tests</b>	UV Absorbance (254 nm) (Abs/cm-1)	0.0120			
	Colour, True (CU)	<5.0			
	Conductivity (uS/cm)	887			
	Hardness (as CaCO3) (ug/L)	433000			
	pH (pH)	8.08			
	Total Suspended Solids (ug/L)	<3000			
	Total Dissolved Solids (ug/L)	634000			
	Transmittance, UV (254 nm) (% T)	97.5			
	Turbidity (NTU)	3.90			
<b>Anions and Nutrients</b>	Alkalinity, Bicarbonate (as CaCO3) (ug/L)	214000			
	Alkalinity, Carbonate (as CaCO3) (ug/L)	<1000			
	Alkalinity, Hydroxide (as CaCO3) (ug/L)	<1000			
	Alkalinity, Total (as CaCO3) (ug/L)	214000			
	Chloride (Cl) (ug/L)	5800			
	Fluoride (F) (ug/L)	<200 <sup>DLM</sup>			
	Nitrate and Nitrite (as N) (ug/L)	<51			
	Nitrate (as N) (ug/L)	<50 <sup>DLM</sup>			
	Nitrite (as N) (ug/L)	14			
	Total Kjeldahl Nitrogen (ug/L)	160			
	Orthophosphate-Dissolved (as P) (ug/L)	<1.0			
	Phosphorus (P)-Total (ug/L)	<2.0			
	Sulfate (SO4) (ug/L)	290000			
<b>Organic / Inorganic Carbon</b>	Dissolved Organic Carbon (ug/L)	1360			
	Total Organic Carbon (ug/L)	1630			
<b>Total Metals</b>	Aluminum (Al)-Total (ug/L)	6.2			
	Antimony (Sb)-Total (ug/L)	0.16			
	Arsenic (As)-Total (ug/L)	0.17			
	Barium (Ba)-Total (ug/L)	13.3			
	Beryllium (Be)-Total (ug/L)	<0.10			
	Bismuth (Bi)-Total (ug/L)	<0.50			
	Boron (B)-Total (ug/L)	35			
	Cadmium (Cd)-Total (ug/L)	<0.010			
	Calcium (Ca)-Total (ug/L)	79500			
	Chromium (Cr)-Total (ug/L)	0.24			
	Cobalt (Co)-Total (ug/L)	<0.10			
	Copper (Cu)-Total (ug/L)	<0.50			

\* Please refer to the Reference Information section for an explanation of any qualifiers detected.

# ALS ENVIRONMENTAL ANALYTICAL REPORT

Sample ID	L1414070-1				
Description	Grab				
Sampled Date	21-JAN-13				
Sampled Time	12:15				
Client ID	DC-2				
Grouping	Analyte				
<b>WATER</b>					
<b>Total Metals</b>	Iron (Fe)-Total (ug/L)	344			
	Lead (Pb)-Total (ug/L)	<0.050			
	Lithium (Li)-Total (ug/L)	21.4			
	Magnesium (Mg)-Total (ug/L)	56600			
	Manganese (Mn)-Total (ug/L)	10.5			
	Mercury (Hg)-Total (ug/L)	<0.010			
	Molybdenum (Mo)-Total (ug/L)	3.54			
	Nickel (Ni)-Total (ug/L)	<0.50			
	Phosphorus (P)-Total (ug/L)	<50			
	Potassium (K)-Total (ug/L)	860			
	Selenium (Se)-Total (ug/L)	<0.10			
	Silicon (Si)-Total (ug/L)	7540			
	Silver (Ag)-Total (ug/L)	<0.010			
	Sodium (Na)-Total (ug/L)	37900			
	Strontium (Sr)-Total (ug/L)	6300			
	Sulfur (S)-Total (ug/L)	94700			
	Thallium (Tl)-Total (ug/L)	<0.010			
	Tin (Sn)-Total (ug/L)	<0.10			
	Titanium (Ti)-Total (ug/L)	<10			
	Uranium (U)-Total (ug/L)	0.085			
	Vanadium (V)-Total (ug/L)	<1.0			
	Zinc (Zn)-Total (ug/L)	<3.0			
<b>Dissolved Metals</b>	Dissolved Mercury Filtration Location	FIELD			
	Dissolved Metals Filtration Location	FIELD			
	Aluminum (Al)-Dissolved (ug/L)	<1.0			
	Antimony (Sb)-Dissolved (ug/L)	0.13			
	Arsenic (As)-Dissolved (ug/L)	<0.10			
	Barium (Ba)-Dissolved (ug/L)	13.1			
	Beryllium (Be)-Dissolved (ug/L)	<0.10			
	Bismuth (Bi)-Dissolved (ug/L)	<0.50			
	Boron (B)-Dissolved (ug/L)	33			
	Cadmium (Cd)-Dissolved (ug/L)	<0.010			
	Calcium (Ca)-Dissolved (ug/L)	80300			
	Chromium (Cr)-Dissolved (ug/L)	0.18			
	Cobalt (Co)-Dissolved (ug/L)	<0.10			
	Copper (Cu)-Dissolved (ug/L)	<0.20			
	Iron (Fe)-Dissolved (ug/L)	342			

\* Please refer to the Reference Information section for an explanation of any qualifiers detected.

# ALS ENVIRONMENTAL ANALYTICAL REPORT

	Sample ID Description Sampled Date Sampled Time Client ID				
	L1414070-1 Grab 21-JAN-13 12:15 DC-2				
Grouping	Analyte				
<b>WATER</b>					
<b>Dissolved Metals</b>	Lead (Pb)-Dissolved (ug/L)	<0.050			
	Lithium (Li)-Dissolved (ug/L)	21.7			
	Magnesium (Mg)-Dissolved (ug/L)	56400			
	Manganese (Mn)-Dissolved (ug/L)	10.2			
	Mercury (Hg)-Dissolved (ug/L)	<0.010			
	Molybdenum (Mo)-Dissolved (ug/L)	3.29			
	Nickel (Ni)-Dissolved (ug/L)	<0.50			
	Phosphorus (P)-Dissolved (ug/L)	<50			
	Potassium (K)-Dissolved (ug/L)	970			
	Selenium (Se)-Dissolved (ug/L)	<0.10			
	Silicon (Si)-Dissolved (ug/L)	7460			
	Silver (Ag)-Dissolved (ug/L)	<0.010			
	Sodium (Na)-Dissolved (ug/L)	37300			
	Strontium (Sr)-Dissolved (ug/L)	6270			
	Sulfur (S)-Dissolved (ug/L)	90000			
	Thallium (Tl)-Dissolved (ug/L)	<0.010			
	Tin (Sn)-Dissolved (ug/L)	<0.10			
	Titanium (Ti)-Dissolved (ug/L)	<10			
	Uranium (U)-Dissolved (ug/L)	0.081			
	Vanadium (V)-Dissolved (ug/L)	<1.0			
	Zinc (Zn)-Dissolved (ug/L)	<1.0			
<b>Speciated Metals</b>	Chromium, Trivalent (ug/L)	<5.0			
	Hexavalent Chromium (ug/L)	<1.0			
	Hexavalent Chromium-Dissolved (ug/L)	<1.0			
<b>Volatile Organic Compounds</b>	Benzene (ug/L)	<0.50			
	Ethylbenzene (ug/L)	<0.50			
	Methyl t-butyl ether (MTBE) (ug/L)	<0.50			
	Styrene (ug/L)	<0.50			
	Toluene (ug/L)	<0.50			
	ortho-Xylene (ug/L)	<0.50			
	meta- & para-Xylene (ug/L)	<0.50			
	Xylenes (ug/L)	<0.75			
	Surrogate: 4-Bromofluorobenzene (SS) (%)	98.7			
	Surrogate: 1,4-Difluorobenzene (SS) (%)	99.8			
<b>Hydrocarbons</b>	EPH10-19 (ug/L)	<250			
	EPH19-32 (ug/L)	<250			
	LEPH (ug/L)	<250			

\* Please refer to the Reference Information section for an explanation of any qualifiers detected.

# ALS ENVIRONMENTAL ANALYTICAL REPORT

	Sample ID Description Sampled Date Sampled Time Client ID				
	L1414070-1 Grab 21-JAN-13 12:15 DC-2				
Grouping	Analyte				
<b>WATER</b>					
<b>Hydrocarbons</b>	HEPH (ug/L)	<250			
	Volatile Hydrocarbons (VH6-10) (ug/L)	<100			
	VPH (C6-C10) (ug/L)	<100			
	Surrogate: 3,4-Dichlorotoluene (SS) (%)	125.9			
<b>Polycyclic Aromatic Hydrocarbons</b>	Acenaphthene (ug/L)	<0.050			
	Acenaphthylene (ug/L)	<0.050			
	Acridine (ug/L)	<0.050			
	Anthracene (ug/L)	<0.050			
	Benz(a)anthracene (ug/L)	<0.050			
	Benzo(a)pyrene (ug/L)	<0.010			
	Benzo(b)fluoranthene (ug/L)	<0.050			
	Benzo(g,h,i)perylene (ug/L)	<0.050			
	Benzo(k)fluoranthene (ug/L)	<0.050			
	Chrysene (ug/L)	<0.050			
	Dibenz(a,h)anthracene (ug/L)	<0.050			
	Fluoranthene (ug/L)	<0.050			
	Fluorene (ug/L)	<0.050			
	Indeno(1,2,3-c,d)pyrene (ug/L)	<0.050			
	Naphthalene (ug/L)	<0.050			
	Phenanthrene (ug/L)	<0.050			
	Pyrene (ug/L)	<0.050			
	Quinoline (ug/L)	<0.050			
	Surrogate: Acenaphthene d10 (%)	87.2			
	Surrogate: Acridine d9 (%)	78.2			
	Surrogate: Chrysene d12 (%)	84.1			
	Surrogate: Naphthalene d8 (%)	86.2			
	Surrogate: Phenanthrene d10 (%)	83.6			

\* Please refer to the Reference Information section for an explanation of any qualifiers detected.



## Reference Information

### QC Samples with Qualifiers & Comments:

QC Type Description	Parameter	Qualifier	Applies to Sample Number(s)
Matrix Spike	Strontium (Sr)-Dissolved	MS-B	L1414070-1
Matrix Spike	Sodium (Na)-Dissolved	MS-B	L1414070-1
Matrix Spike	Strontium (Sr)-Dissolved	MS-B	L1414070-1
Matrix Spike	Barium (Ba)-Dissolved	MS-B	L1414070-1
Matrix Spike	Cadmium (Cd)-Dissolved	MS-B	L1414070-1
Matrix Spike	Manganese (Mn)-Dissolved	MS-B	L1414070-1
Matrix Spike	Strontium (Sr)-Dissolved	MS-B	L1414070-1
Matrix Spike	Total Kjeldahl Nitrogen	MSTN	L1414070-1

### Qualifiers for Individual Parameters Listed:

Qualifier	Description
DLM	Detection Limit Adjusted due to sample matrix effects.
MS-B	Matrix Spike recovery could not be accurately calculated due to high analyte background in sample.
MSTN	TKN Matrix Spike recovery was low due to interference from high nitrate, which causes negative bias on TKN.

### Test Method References:

ALS Test Code	Matrix	Test Description	Method Reference**
<b>ALK-PCT-VA</b>	Water	Alkalinity by Auto. Titration	APHA 2320 "Alkalinity"
		This analysis is carried out using procedures adapted from APHA Method 2320 "Alkalinity". Total alkalinity is determined by potentiometric titration to a pH 4.5 endpoint. Bicarbonate, carbonate and hydroxide alkalinity are calculated from phenolphthalein alkalinity and total alkalinity values.	
<b>ALK-PCT-VA</b>	Water	Alkalinity by Auto. Titration	APHA 2320 Alkalinity
		This analysis is carried out using procedures adapted from APHA Method 2320 "Alkalinity". Total alkalinity is determined by potentiometric titration to a pH 4.5 endpoint. Bicarbonate, carbonate and hydroxide alkalinity are calculated from phenolphthalein alkalinity and total alkalinity values.	
<b>ANIONS-CL-IC-VA</b>	Water	Chloride by Ion Chromatography	APHA 4110 B.
		This analysis is carried out using procedures adapted from APHA Method 4110 B. "Ion Chromatography with Chemical Suppression of Eluent Conductivity" and EPA Method 300.0 "Determination of Inorganic Anions by Ion Chromatography".	
<b>ANIONS-F-IC-VA</b>	Water	Fluoride by Ion Chromatography	APHA 4110 B.
		This analysis is carried out using procedures adapted from APHA Method 4110 B. "Ion Chromatography with Chemical Suppression of Eluent Conductivity" and EPA Method 300.0 "Determination of Inorganic Anions by Ion Chromatography".	
<b>ANIONS-N+N-CALC-VA</b>	Water	Nitrite & Nitrate in Water (Calculation)	EPA 300.0
		Nitrate and Nitrite (as N) is a calculated parameter. Nitrate and Nitrite (as N) = Nitrite (as N) + Nitrate (as N).	
<b>ANIONS-NO2-IC-VA</b>	Water	Nitrite in Water by Ion Chromatography	EPA 300.0
		This analysis is carried out using procedures adapted from EPA Method 300.0 "Determination of Inorganic Anions by Ion Chromatography". Nitrite is detected by UV absorbance.	
<b>ANIONS-NO3-IC-VA</b>	Water	Nitrate in Water by Ion Chromatography	EPA 300.0
		This analysis is carried out using procedures adapted from EPA Method 300.0 "Determination of Inorganic Anions by Ion Chromatography". Nitrate is detected by UV absorbance.	
<b>ANIONS-SO4-IC-VA</b>	Water	Sulfate by Ion Chromatography	APHA 4110 B.
		This analysis is carried out using procedures adapted from APHA Method 4110 B. "Ion Chromatography with Chemical Suppression of Eluent Conductivity" and EPA Method 300.0 "Determination of Inorganic Anions by Ion Chromatography".	
<b>CARBONS-DOC-VA</b>	Water	Dissolved organic carbon by combustion	APHA 5310 TOTAL ORGANIC CARBON (TOC)
		This analysis is carried out using procedures adapted from APHA Method 5310 "Total Organic Carbon (TOC)". Dissolved carbon (DOC) fractions are determined by filtering the sample through a 0.45 micron membrane filter prior to analysis.	
<b>CARBONS-TOC-VA</b>	Water	Total organic carbon by combustion	APHA 5310 TOTAL ORGANIC CARBON (TOC)
		This analysis is carried out using procedures adapted from APHA Method 5310 "Total Organic Carbon (TOC)".	
<b>COLOUR-TRUE-VA</b>	Water	Colour (True) by Spectrometer	BCMOE Colour Single Wavelength
		This analysis is carried out using procedures adapted from British Columbia Environmental Manual "Colour- Single Wavelength." Colour (True Colour) is determined by filtering a sample through a 0.45 micron membrane filter followed by analysis of the filtrate using the platinum-cobalt colourimetric method. Apparent Colour is determined without prior sample filtration. Colour is pH dependent. Unless otherwise indicated, reported colour results pertain to the pH of the sample as received, to within +/- 1 pH unit.	
<b>CR-CR3-ED</b>	Water	Chromium, Trivalent (Cr +3)	Total Dissolved Cr - Cr(+6)
		Chromium (III) is calculated as the difference between Total Chromium and Chromium (VI) results.	
<b>CR-CR6-ED</b>	Water	Chromium, Hexavalent (Cr +6)	APHA 3500-Cr C (Ion Chromatography)

## Reference Information

This analysis is carried out using procedures adapted from method 3500-Cr C in "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from Method 1636 published by the United States Environmental Protection Agency (EPA). The procedure involves analysis for chromium (VI) by ion chromatography using diphenylcarbazide in a sulphuric acid solution.

Results are based on an un-filtered, field-preserved sample.

**CR6-D-IC-ED** Water Chromium, Dissolved Hexavalent (Cr +6) APHA 3500-Cr C (Ion Chromatography)

This analysis is carried out using procedures adapted from method 3500-Cr C in "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from Method 1636 published by the United States Environmental Protection Agency (EPA). The procedure involves analysis for chromium (VI) by ion chromatography using diphenylcarbazide in a sulphuric acid solution.

Results are based on a field-filtered, field-preserved sample.

**EC-PCT-VA** Water Conductivity (Automated) APHA 2510 Auto. Conduc.

This analysis is carried out using procedures adapted from APHA Method 2510 "Conductivity". Conductivity is determined using a conductivity electrode.

**EPH-SF-FID-VA** Water EPH in Water by Tumbler and GCFID BC MOE EPH GCFID

Analysis is in accordance with BC MOE Lab Manual method "Extractable Petroleum Hydrocarbons in Water by GC/FID", v2.1, July 1999. Whole water samples are extracted with DCM prior to gas chromatography with flame ionization detection (GC-FID). EPH results include Polycyclic Aromatic Hydrocarbons (PAH) and are therefore not equivalent to Light and Heavy Extractable Petroleum Hydrocarbons (LEPH/HEPH).

**HARDNESS-CALC-VA** Water Hardness APHA 2340B

Hardness (also known as Total Hardness) is calculated from the sum of Calcium and Magnesium concentrations, expressed in CaCO<sub>3</sub> equivalents. Dissolved Calcium and Magnesium concentrations are preferentially used for the hardness calculation.

**HG-DIS-LOW-CVAFS-VA** Water Dissolved Mercury in Water by CVAFS(Low) EPA SW-846 3005A & EPA 245.7

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedures may involve preliminary sample treatment by filtration (EPA Method 3005A) and involves a cold-oxidation of the acidified sample using bromine monochloride prior to reduction of the sample with stannous chloride. Instrumental analysis is by cold vapour atomic fluorescence spectrophotometry or atomic absorption spectrophotometry (EPA Method 245.7).

**HG-TOT-LOW-CVAFS-VA** Water Total Mercury in Water by CVAFS(Low) EPA 245.7

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedure involves a cold-oxidation of the acidified sample using bromine monochloride prior to reduction of the sample with stannous chloride. Instrumental analysis is by cold vapour atomic fluorescence spectrophotometry or atomic absorption spectrophotometry (EPA Method 245.7).

**LEPH/HEPH-CALC-VA** Water LEPHs and HEPHs BC MOE LABORATORY MANUAL (2005)

Light and Heavy Extractable Petroleum Hydrocarbons in water. These results are determined according to the British Columbia Ministry of Environment, Lands, and Parks Analytical Method for Contaminated Sites "Calculation of Light and Heavy Extractable Petroleum Hydrocarbons in Solids or Water". According to this method, LEPH and HEPH are calculated by subtracting selected Polycyclic Aromatic Hydrocarbon results from Extractable Petroleum Hydrocarbon results. To calculate LEPH, the individual results for Acenaphthene, Acridine, Anthracene, Fluorene, Naphthalene and Phenanthrene are subtracted from EPH(C10-19). To calculate HEPH, the individual results for Benz(a)anthracene, Benzo(a)pyrene, Fluoranthene, and Pyrene are subtracted from EPH(C19-32). Analysis of Extractable Petroleum Hydrocarbons adheres to all prescribed elements of the BCMELP method "Extractable Petroleum Hydrocarbons in Water by GC/FID" (Version 2.1, July 20, 1999).

**MET-D-CCMS-VA** Water Dissolved Metals in Water by CRC ICPMS APHA 3030 B&E / EPA SW-846 6020A

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedures may involve preliminary sample treatment by acid digestion, using hotblock, or filtration (APHA 3030B&E). Instrumental analysis is by collision cell inductively coupled plasma - mass spectrometry (modified from EPA Method 6020A).

**MET-DIS-LOW-ICP-VA** Water Dissolved Metals in Water by ICPOES EPA 3005A/6010B

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedure involves filtration (EPA Method 3005A) and analysis by inductively coupled plasma - optical emission spectrophotometry (EPA Method 6010B).

**MET-T-CCMS-VA** Water Total Metals in Water by CRC ICPMS APHA 3030 B&E / EPA SW-846 6020A

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedures may involve preliminary sample treatment by acid digestion, using hotblock, or filtration (APHA 3030B&E). Instrumental analysis is by collision cell inductively coupled plasma - mass spectrometry (modified from EPA Method 6020A).

**MET-TOT-LOW-ICP-VA** Water Total Metals in Water by ICPOES EPA 3005A/6010B

## Reference Information

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedures may involve preliminary sample treatment by acid digestion, using either hotblock or microwave oven (EPA Method 3005A). Instrumental analysis is by inductively coupled plasma - optical emission spectrophotometry (EPA Method 6010B).

**P-T-COL-VA**                      Water              Total P in Water by Colour    APHA 4500-P Phosphorous

This analysis is carried out using procedures adapted from APHA Method 4500-P "Phosphorus". Total Phosphorous is determined colourimetrically after persulphate digestion of the sample.

**PAH-SF-MS-VA**                      Water              PAH in Water by GCMS    EPA 3510, 8270

The entire water sample is extracted with dichloromethane, prior to analysis by gas chromatography with mass spectrometric detection (GC/MS). Because the two isomers cannot be readily chromatographically separated, benzo(j)fluoranthene is reported as part of the benzo(b)fluoranthene parameter.

**PAH-SURR-MS-VA**                      Water              PAH Surrogates for Waters    EPA 3510, 8270

Analysed as per the corresponding PAH test method. Known quantities of surrogate compounds are added prior to analysis to each sample to demonstrate analytical accuracy.

**PH-PCT-VA**                      Water              pH by Meter (Automated)    APHA 4500-H "pH Value"

This analysis is carried out using procedures adapted from APHA Method 4500-H "pH Value". The pH is determined in the laboratory using a pH electrode

It is recommended that this analysis be conducted in the field.

**PH-PCT-VA**                      Water              pH by Meter (Automated)    APHA 4500-H pH Value

This analysis is carried out using procedures adapted from APHA Method 4500-H "pH Value". The pH is determined in the laboratory using a pH electrode

It is recommended that this analysis be conducted in the field.

**PO4-DO-COL-VA**                      Water              Diss. Orthophosphate in Water by Colour    APHA 4500-P Phosphorous

This analysis is carried out using procedures adapted from APHA Method 4500-P "Phosphorus". Dissolved Orthophosphate is determined colourimetrically on a sample that has been lab or field filtered through a 0.45 micron membrane filter.

**S-DIS-ICP-VA**                      Water              Dissolved Sulfur in Water by ICPOES    EPA SW-846 3005A/6010B

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedures may involve preliminary sample treatment by acid digestion, using either hotblock or microwave oven, or filtration (EPA Method 3005A). Instrumental analysis is by inductively coupled plasma - optical emission spectrophotometry (EPA Method 6010B).

Method Limitation: This method will not give total sulfur results for all samples. Sulfide or other volatile forms of sulfur that may be present in submitted samples, is often lost during the sampling, preservation and analysis process. The data reported as total and/or dissolved sulfur represents all non-volatile forms of sulfur present in a particular sample.

**S-TOT-ICP-VA**                      Water              Total Sulfur in Water by ICPOES    EPA SW-846 3005A/6010B

This analysis is carried out using procedures adapted from "Standard Methods for the Examination of Water and Wastewater" published by the American Public Health Association, and with procedures adapted from "Test Methods for Evaluating Solid Waste" SW-846 published by the United States Environmental Protection Agency (EPA). The procedures may involve preliminary sample treatment by acid digestion, using either hotblock or microwave oven, or filtration (EPA Method 3005A). Instrumental analysis is by inductively coupled plasma - optical emission spectrophotometry (EPA Method 6010B).

Method Limitation: This method will not give total sulfur results for all samples. Sulfide or other volatile forms of sulfur that may be present in submitted samples, is often lost during the sampling, preservation and analysis process. The data reported as total and/or dissolved sulfur represents all non-volatile forms of sulfur present in a particular sample.

**TDS-VA**                      Water              Total Dissolved Solids by Gravimetric    APHA 2540 C - GRAVIMETRIC

This analysis is carried out using procedures adapted from APHA Method 2540 "Solids". Solids are determined gravimetrically. Total Dissolved Solids (TDS) are determined by filtering a sample through a glass fibre filter, TDS is determined by evaporating the filtrate to dryness at 180 degrees celsius.

**TKN-F-VA**                      Water              TKN in Water by Fluorescence    APHA 4500-NORG D.

This analysis is carried out using procedures adapted from APHA Method 4500-Norg D. "Block Digestion and Flow Injection Analysis". Total Kjeldahl Nitrogen is determined using block digestion followed by Flow-injection analysis with fluorescence detection.

**TSS-VA**                      Water              Total Suspended Solids by Gravimetric    APHA 2540 D - GRAVIMETRIC

This analysis is carried out using procedures adapted from APHA Method 2540 "Solids". Solids are determined gravimetrically. Total Suspended Solids (TSS) are determined by filtering a sample through a glass fibre filter, TSS is determined by drying the filter at 104 degrees celsius.

**TURBIDITY-VA**                      Water              Turbidity by Meter    APHA 2130 "Turbidity"

This analysis is carried out using procedures adapted from APHA Method 2130 "Turbidity". Turbidity is determined by the nephelometric method.

## Reference Information

<b>TURBIDITY-VA</b>	Water	Turbidity by Meter	APHA 2130 Turbidity
This analysis is carried out using procedures adapted from APHA Method 2130 "Turbidity". Turbidity is determined by the nephelometric method.			
<b>UV-%TRANS-VA</b>	Water	% Transmittance by Spectrometry	APHA 5910B UV ABSORPTION METHOD
This analysis is carried out using procedures adapted from APHA Method 5910B "Ultraviolet Absorption Method" and Method 415.3 "Determination of Total Organic Carbon and Specific UV Absorbance at 254nm in Source Water and Drinking Water", published by the United States Environmental Protection Agency (EPA). The sample is filtered through a 0.45um filter and measured for absorbance in a quartz cell at 254nm and reported as % Transmittance. The analysis is carried out without pH adjustment.			
<b>UV-ABS-VA</b>	Water	UV Absorbance by Spectrometry	APHA 5910B UV ABSORPTION METHOD
This analysis is carried out using procedures adapted from APHA Method 5910B "Ultraviolet Absorption Method" and Method 415.3 "Determination of Total Organic Carbon and Specific UV Absorbance at 254nm in Source Water and Drinking Water", published by the United States Environmental Protection Agency (EPA). The sample is filtered through a 0.45um filter and measured for absorbance in a quartz cell at 254nm and reported as absorbance per cm (i.e. cm <sup>-1</sup> ). The analysis is carried out without pH adjustment. Alternatively, results can be reported as % Transmittance (over one cm) where the absorbance result is converted to % Transmittance by the following calculation: %T = 100(10 to the power of -A).			
<b>VH-HSFID-VA</b>	Water	VH in Water by Headspace GCFID	B.C. MIN. OF ENV. LAB. MAN. (2009)
The water sample, with added reagents, is heated in a sealed vial to equilibrium. The headspace from the vial is transferred into a gas chromatograph. Compounds eluting between n-hexane and n-decane are measured and summed together using flame-ionization detection.			
<b>VH-SURR-FID-VA</b>	Water	VH Surrogates for Waters	B.C. MIN. OF ENV. LAB. MAN. (2009)
<b>VOC7-HSMS-VA</b>	Water	BTEX/MTBE/Styrene by Headspace GCMS	EPA8260B, 5021
The water sample, with added reagents, is heated in a sealed vial to equilibrium. The headspace from the vial is transferred into a gas chromatograph. Target compound concentrations are measured using mass spectrometry detection.			
<b>VOC7/VOC-SURR-MS-VA</b>	Water	VOC7 and/or VOC Surrogates for Waters	EPA8260B, 5021
<b>VPH-CALC-VA</b>	Water	VPH is VH minus select aromatics	BC MOE LABORATORY MANUAL (2005)
These results are determined according to the British Columbia Ministry of Environment Analytical Method for Contaminated Sites "Calculation of Volatile Petroleum Hydrocarbons in Solids or Water". The concentrations of specific Monocyclic Aromatic Hydrocarbons (Benzene, Toluene, Ethylbenzene, Xylenes and, in solids, Styrene) are subtracted from the collective concentration of Volatile Hydrocarbons (VH) that elute between n-hexane (nC6) and n-decane (nC10).			
<b>XYLENES-CALC-VA</b>	Water	Sum of Xylene Isomer Concentrations	CALCULATION
Calculation of Total Xylenes			
Total Xylenes is the sum of the concentrations of the ortho, meta, and para Xylene isomers. Results below detection limit (DL) are treated as zero. The DL for Total Xylenes is set to a value no less than the square root of the sum of the squares of the DLs of the individual Xylenes.			

\*\* ALS test methods may incorporate modifications from specified reference methods to improve performance.

*The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:*

Laboratory Definition Code	Laboratory Location
ED	ALS ENVIRONMENTAL - EDMONTON, ALBERTA, CANADA
VA	ALS ENVIRONMENTAL - VANCOUVER, BRITISH COLUMBIA, CANADA

### Chain of Custody Numbers:

10-267432

### GLOSSARY OF REPORT TERMS

*Surrogate - A compound that is similar in behaviour to target analyte(s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.*

*mg/kg - milligrams per kilogram based on dry weight of sample.*

*mg/kg wwt - milligrams per kilogram based on wet weight of sample.*

*mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight of sample.*

*mg/L - milligrams per litre.*

*< - Less than.*

*D.L. - The reported Detection Limit, also known as the Limit of Reporting (LOR).*

*N/A - Result not available. Refer to qualifier code and definition for explanation.*

*Test results reported relate only to the samples as received by the laboratory.*


**UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.**

*Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.*

# Hydrocarbon Distribution Report



ALS Sample ID: L1414070-1  
Client Sample ID: DC-2



nC10	nC19	nC32
174°C	330°C	467°C
346°F	626°F	873°F
← Gasoline →		← Motor Oils / Lube Oils / Grease →
← Diesel / Jet Fuels →		

The EPH Hydrocarbon Distribution Report (HDR) is intended to assist you in characterizing hydrocarbon products that may be present in your sample. For further interpretation, a current library of reference products is available on [www.alsglobal.com](http://www.alsglobal.com) or upon request.

The scale at the bottom of the chromatogram indicates the approximate retention times of common petroleum products, and three n-alkane hydrocarbon marker compounds. Retention times may vary between samples by as much as 0.5 minutes.

Peak heights in this report are a function of the sample concentration, the sample amount extracted, the sample dilution factor, and the response scale at the left.

A "-L-" in the sample ID denotes a low level sample. A "-S-" denotes a silica gel cleaned sample.



Chain of Custody / Analytical Request Form  
 Canada Toll Free: 1 800 668 9878  
 www.alsglobal.com

<b>Report To</b>	<b>Report Format / Distribution</b>	<b>Service Request:</b> (Rush subject to availability - Contact ALS to confirm TAT)
Company: <b>EBA</b>	Standard: <input checked="" type="checkbox"/> Other (specify):	<input checked="" type="checkbox"/> Regular (Standard Turnaround Times - Business Days)
Contact: <b>Gareth Earl</b>	Select: PDF <input checked="" type="checkbox"/> Excel Digital Fax	Priority(2-4 Business Days)-50% surcharge - Contact ALS to confirm TAT
Address: <b>61 Wasson Rd. Whitehorse</b>	Email 1: <b>gearl@eba.ca.</b>	Emergency (1-2 Business Days)-100% Surcharge - Contact ALS to confirm TAT
Phone: <b>868-9221</b> Fax:	Email 2:	Same Day or Weekend Emergency - Contact ALS to confirm TAT

<b>Invoice To</b> Same as Report? (circle) Yes or No (if No, provide details)	<b>Client / Project Information</b>	<b>Analysis Request</b> (Indicate Filtered or Preserved, F/P)									
Copy of Invoice with Report? (circle) Yes or No	Job #: <b>ENVH2003020-01</b>										
Company:	PO / AFE:										
Contact:	LSD:										
Address:	Quote #: <b>Q43394</b>										
Phone: Fax:	ALS Contact:										
<b>Lab Work Order # (lab use only)</b>	Sampler: <b>Kristen Renge</b>										

Sample #	Sample Identification (This description will appear on the report)	Date (dd-mmm-yy)	Time (hh:mm)	Sample Type	GENERAL	DOC	TAC/TKW	TOTAL METALS (LOW)	DISSOLVED METALS (LOW)	TOTAL/DISSOLVED (P+D)	BTEX + STROBENHAP	LEPH/HEPH+PAH	Number of Containers
	Bottle order BR114872 including total + dissolved metals and anion DC-2	21/Jun/14	12:15pm	grab.	X	X	X	X	X	X	X	X	



L1414070-COFC

Special Instructions / Regulation with water or land use (CCME- Freshwater Aquatic Life/BC CSR-Commercial/AB Tier 1-Natural/ETC) / Hazardous Details

Ref. Bottle order #BR114872

Failure to complete all portions of this form may delay analysis. Please fill in this form LEGIBLY.

By the use of this form the user acknowledges and agrees with the Terms and Conditions as specified on the back page of the white - report copy.

<b>SHIPMENT RELEASE (client use)</b>			<b>SHIPMENT RECEPTION (lab use only)</b>				<b>SHIPMENT VERIFICATION (lab use only)</b>			
Released by:	Date:	Time:	Received by:	Date:	Time:	Temperature:	Verified by:	Date:	Time:	Observations: Yes / No ? If Yes add SIF
			<i>[Signature]</i>	21-JUN-14	2:55	2.8 °C				

## Report Transmission Cover Page

Bill To: Tetra Tech EBA Inc	Project:	Lot ID: <b>982383</b>
Report To: Tetra Tech EBA Inc	ID: ENVH2O03020	Control Number:
61 Wasson Place	Name:	Date Received: Jan 22, 2014
Whitehorse, YT, Canada	Location: Deep Creek	Date Reported: Feb 6, 2014
Y1A 0H7	LSD:	Report Number: 1890586
Attn: Gareth Earl	P.O.:	
Sampled By: Kristen Range	Acct code:	
Company: EBA		

---

Contact & Affiliation	Address	Delivery Commitments
Ryan Martin Tetra Tech EBA Inc - Edmonton	61 Wasson Place Whitehorse, Yukon Territory Y1A 0H7 Phone: (867) 668-3068 Fax: (867) 668-4349 Email: ryan.martin@tetrattech.com	On [Report Approval] send (Test Report, COC) by Email - Merge Reports On [Report Approval] send (Test Report) by Email - Single Report On [Report Approval] send (Test Report) by Email - Single Report
Ingrid Fuller Tetra Tech EBA Inc - Edmonton	61 Wasson Place, Whitehorse, Yukon Territory Y1A 0H7 Phone: (867) 668-2071 Fax: (867) 668-4349 Email: ifuller@eba.ca	On [Lot Approval and Final Test Report Approval] send (Invoice) by Email - Single Report
Gareth Earl Tetra Tech EBA Inc - Edmonton	61 Wasson Place Whitehorse, Yukon Territory Y1A 0H7 Phone: (867) 668-3068 Fax: (867) 668-4349 Email: Gareth.Earl@tetrattech.com	On [Lot Verification] send (COA) by Email - Single Report On [Report Approval] send (COC, Test Report) by Email - Merge Reports On [Report Approval] send (Test Report) by Email - Single Report On [Report Approval] send (Test Report) by Email - Single Report On [Lot Creation] send (COR) by Email - Single Report

---

### Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

**Sample Custody**

Bill To: Tetra Tech EBA Inc	Project:	Lot ID: <b>982383</b>
Report To: Tetra Tech EBA Inc	ID: ENVH2O03020	Control Number:
61 Wasson Place	Name:	Date Received: Jan 22, 2014
Whitehorse, YT, Canada	Location: Deep Creek	Date Reported: Feb 6, 2014
Y1A 0H7	LSD:	Report Number: 1890586
Attn: Gareth Earl	P.O.:	
Sampled By: Kristen Range	Acct code:	
Company: EBA		

---

**Sample Disposal Date: May 07, 2014**

All samples will be stored until this date unless other instructions are received. Please indicate other requirements below and return this form to the address or fax number on the top of this page.

Extend Sample Storage Until \_\_\_\_\_ (MM/DD/YY)

The following charges apply to extended sample storage:

Storage for an additional 30 days	\$ 2.50 per sample
Storage for an additional 60 days	\$ 5.00 per sample
Storage for an additional 90 days	\$ 7.50 per sample

Return Sample, collect, to the address below via:

Greyhound

DHL

Purolator

Other (specify) \_\_\_\_\_

Name \_\_\_\_\_

Company \_\_\_\_\_

Address \_\_\_\_\_

Phone \_\_\_\_\_

Fax \_\_\_\_\_

Signature \_\_\_\_\_





**Analytical Report**

Bill To: Tetra Tech EBA Inc  
 Report To: Tetra Tech EBA Inc  
 61 Wasson Place  
 Whitehorse, YT, Canada  
 Y1A 0H7  
 Attn: Gareth Earl  
 Sampled By: Kristen Range  
 Company: EBA

Project:  
 ID: ENVH2O03020  
 Name:  
 Location: Deep Creek  
 LSD:  
 P.O.:  
 Acct code:

Lot ID: **982383**  
 Control Number:  
 Date Received: Jan 22, 2014  
 Date Reported: Feb 6, 2014  
 Report Number: 1890586

**Reference Number** 982383-1  
**Sample Date** Jan 21, 2014  
**Sample Time** 13:00  
**Sample Location**  
**Sample Description** DC-2  
**Matrix** Water

Analyte	Units	Results	Results	Results	Nominal Detection Limit
<b>Routine Water</b>					
pH	at 25 °C	pH	7.69		
<b>Trihalomethane Formation Potential</b>					
pH adjustment	required prior to THMFP		No		
Chlorine	spike concentration	mg/L	5.0		0.1
Incubation Time		Days	7		1
Chlorine	final after incubation	mg/L	3.3		0.1
Bromodichloromethane		mg/L	0.004		0.001
Bromoform		mg/L	<0.001		0.001
Chloroform		mg/L	0.017		0.001
Dibromochloromethane		mg/L	0.002		0.001
Total Trihalomethanes		mg/L	0.023		0.001
<b>Trihalomethanes - Surrogate Recovery</b>					
Dibromofluoromethane	EPA Surrogate	%	91		86-118
Toluene-d8	EPA Surrogate	%	98		88-110
Bromofluorobenzene	EPA Surrogate	%	109		86-115

Approved by:   
 Mathieu Simoneau  
 Operations Manager



## Quality Control

Bill To: Tetra Tech EBA Inc	Project:	Lot ID: <b>982383</b>
Report To: Tetra Tech EBA Inc	ID: ENVH2O03020	Control Number:
61 Wasson Place	Name:	Date Received: Jan 22, 2014
Whitehorse, YT, Canada	Location: Deep Creek	Date Reported: Feb 6, 2014
Y1A 0H7	LSD:	Report Number: 1890586
Attn: Gareth Earl	P.O.:	
Sampled By: Kristen Range	Acct code:	
Company: EBA		

---

## Routine Water

Client Sample	Replicates	Units	Replicate 1	Replicate 2	% RSD Criteria	Absolute Criteria	Passed QC
pH		pH	7.11	7.07	0	0.50	yes
Date Acquired:		January 22, 2014					
Control Sample		Units	Measured	Lower Limit	Upper Limit		Passed QC
pH		pH	4.10	3.88	4.12		yes
Date Acquired:		January 22, 2014					
pH		pH	8.01	7.88	8.12		yes
Date Acquired:		January 22, 2014					

## Methodology and Notes

Bill To: Tetra Tech EBA Inc	Project:	Lot ID: <b>982383</b>
Report To: Tetra Tech EBA Inc	ID: ENVH2O03020	Control Number:
61 Wasson Place	Name:	Date Received: Jan 22, 2014
Whitehorse, YT, Canada	Location: Deep Creek	Date Reported: Feb 6, 2014
Y1A 0H7	LSD:	Report Number: 1890586
Attn: Gareth Earl	P.O.:	
Sampled By: Kristen Range	Acct code:	
Company: EBA		

---

## Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
pH in water (Surrey)	APHA	* pH - Electrometric Method, 4500-H+ B	22-Jan-14	Exova Surrey
Preparation - THM Formation Potential (Surrey)	APHA	* THM Potential, 5710 B	22-Jan-14	Exova Surrey
THM - PrepWater	US EPA	* US EPA method, 524	31-Jan-14	Exova Calgary

*\* Reference Method Modified*

## References

APHA	Standard Methods for the Examination of Water and Wastewater
US EPA	US Environmental Protection Agency Test Methods

## Comments:

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.





Health and Social Services  
Santé et Affaires sociales  
Environmental Health Services  
Service d'hygiène du milieu

**BACTERIOLOGICAL ANALYSIS OF DRINKING WATER**  
**ANALYSE BACTÉRIOLOGIQUE DE L'EAU POTABLE**

#2 Hospital Road, Whitehorse, Yukon Y1A 3H8  
phone : (867) 667-8391 fax : (867) 667-8322  
Toll free: 1-800-661-0408 ext.8391

2 Hospital Road, Whitehorse (Yukon) Y1A 3H8  
Tél. : 867-667-8391 Téléc. : 867-667-8322  
Sans frais au Yukon : 1-800-661-0408, poste 8391

**Contact Information • Coordonnées de la personne ressource**

Contact Person / Personne ressource: Kristen Range (EBA) Phone / Téléphone: 667-9233  
Mailing address / Adresse postale: 61 Wasoon Place Fax / Télécopieur: 668-4243  
Postal code / Code postal: \_\_\_\_\_  
First Nation, Municipal or Business Name / Nom de la Première nation, de la municipalité ou de l'entreprise: EBA ENGINEERING  
Agent / Agent: \_\_\_\_\_ Fax / Télécopieur: \_\_\_\_\_

**Sampling Location • Lieu de la prise d'échantillon**

Municipal Address / Adresse municipale: DC-2 'Deep Creek' Subdivision / Lotissement: Deep Creek  
Legal Description Lot / Désignation officielle Lot: \_\_\_\_\_ Quad / Quadrilatère: \_\_\_\_\_ Plan no. / Plan n°: \_\_\_\_\_  
Other information (e.g., Location, Business / Building Name) / Autres renseignements (ex.: emplacement, nom de l'entreprise, nom de l'édifice): \_\_\_\_\_

**Sample Collection / Prélèvement de l'échantillon**

Sample Collected By / Échantillon prélevé par: Kristen Range Date / Date: 14/01/21 Time / Heure: 2:25 am/pm  
YY/MM/DD • AA/MM/JJ

Sampling Site (e.g., kitchen tap) / Point d'échantillonnage (ex.: robinet de cuisine): Sampling Tap  
Is this a Resample from a Previous Test? / Est-ce un deuxième échantillon d'un test antérieur?  Yes / Oui  No / Non Previous Sample Number / Numéro de l'échantillon précédent: \_\_\_\_\_

**Sample Supply / Source d'approvisionnement en eau**

Public Supply / Municipal - par canalisation  Bulk Water Distributor / Municipal - par camion  Business / Privé - entreprise  Private Residence / Privé - résidence

**Sample Source / Provenance de l'échantillon**

Dug Well / Puits creusé  Driven Well / Puits tubulaire  Drilled Well / Puits foré à la sondeuse Depth of Well / Profondeur du puits: 400ft  
 Water Holding Tank / Réservoir d'eau  Other (explain) / Autre (précisez): \_\_\_\_\_

**Water Treatment / Traitement de l'eau**

Is the Water Chlorinated? / L'eau contient-elle du chlore?  Yes / Oui  No / Non Free Available Chlorine / Chlore libre disponible: \_\_\_\_\_ ppm / mg/L

Other Treatment Systems (e.g., UV, softener, filter) / Autre dispositif de traitement (ex.: désinfection aux rayons UV, adoucisseur d'eau, filtre): \_\_\_\_\_

**For Laboratory Use Only / À l'usage du laboratoire seulement**

Receipt of Sample / Réception de l'échantillon Date / Date: 14-01-21 Time / Heure: 2:45 am/pm By / Par: SS  
YY/MM/DD • AA/MM/JJ  
Condition of Sample / État de l'échantillon  Satisfactory / Satisfaisant  Unsatisfactory / Non satisfaisant Details / Précisez: 2.2°C  
Incubation / Incubation Date / Date: 14-01-21 Time / Heure: 3:00 am/pm By / Par: SS Incubator / Incubateur: 1  
YY/MM/DD • AA/MM/JJ  
Analysis Completed / Analyse terminée Date / Date: 14-01-22 Time / Heure: 3:35 am/pm By / Par: SS  
YY/MM/DD • AA/MM/JJ

**Results (See Reverse Side for Interpretation) per 100 ml**  
**Résultats (Voir au verso l'interprétation des résultats)**

**Total Coliforms/Coliformes totaux**

Present / Présence  Absent / Absence

**E. coli/E. coli**

Present / Présence  Absent / Absence

**Comments / Commentaires**

Feb 04, 2014

# ***SRC ANALYTICAL***

422 Downey Road  
Saskatoon, Saskatchewan, Canada  
S7N 4N1  
(306) 933-6932 or 1-800-240-8808

Tetra Tech EBA  
61 Wasson Place  
Whitehorse, Yukon Y1A 0H7  
Attn: Kristen Range

Date Samples Received: Jan-31-2014

Client P.O.: ENVH2O03020-01

---

This is a final report.

Organics results have been authorized by Pat Moser, Supervisor

ICP results have been authorized by Keith Gipman, Supervisor

Inorganics and Radiochemistry results have been authorized by Jeff Zimmer, Supervisor

SLOWPOKE-2 results have been authorized by Dave Chorney

---

\* Test methods and data are validated by the laboratory's Quality Assurance Program.

\* Routine methods follow recognized procedures from sources such as

- \* Standard Methods for the Examination of Water and Wastewater APHA AWWA WEF
- \* Environment Canada
- \* US EPA
- \* CANMET

\* The results reported relate only to the test samples as provided by the client.

\* Samples will be kept for 30 days after the final report is sent. Please contact the lab if you have any special requirements.

\* Additional information is available upon request.

Feb 04, 2014

# SRC ANALYTICAL

422 Downey Road  
 Saskatoon, Saskatchewan, Canada  
 S7N 4N1  
 (306) 933-6932 or 1-800-240-8808

Tetra Tech EBA  
 61 Wasson Place  
 Whitehorse, Yukon Y1A 0H7  
 Attn: Kristen Range

Date Samples Received: Jan-31-2014

Client P.O.: ENVH2O03020-01

**3094**      **01/21/2014 12:15 DC-2 \*WATER\***

Analyte	Units	3094
<b>Radio Chemistry</b>		
Gross alpha	Bq/L	0.74±0.27
Gross beta	Bq/L	0.74±0.13

# APPENDIX F

## YUKON CONTAMINATED SITE RECORDS AND YUKON GOVERNMENT CORRESPONDENCE

---



## Range, Kristen

---

**From:** Dickson, Rob  
**Sent:** Thursday, February 20, 2014 2:55 PM  
**To:** Range, Kristen  
**Subject:** FW: ENVH2O03020 Well Head Protection Plan, Lot 1009, Deep Creek, Yukon  
**Attachments:** RE: W23103085 Well Head Protection Plan, Lot 1009, Deep Creek, Yukon

---

**From:** [Bethany.Peters@gov.yk.ca](mailto:Bethany.Peters@gov.yk.ca) [<mailto:Bethany.Peters@gov.yk.ca>]  
**Sent:** Tuesday, February 11, 2014 11:11 AM  
**To:** Dickson, Rob  
**Subject:** RE: ENVH2O03020 Well Head Protection Plan, Lot 1009, Deep Creek, Yukon

Hi Rob,

I just did a quick search of the Spills Database, and there have been no additions since the last time I did a contaminated sites file review search for you (attached email).

Cheers,

**Bethany Peters**  
*Environmental Protection Analyst*  
Environment Yukon  
P: 867.667.8848 F: 867.393.6205  
e: [Bethany.Peters@gov.yk.ca](mailto:Bethany.Peters@gov.yk.ca)

---

**From:** Dickson, Rob [<mailto:Rob.Dickson@tetrattech.com>]  
**Sent:** Tuesday, February 11, 2014 11:07 AM  
**To:** Bethany.Peters  
**Subject:** ENVH2O03020 Well Head Protection Plan, Lot 1009, Deep Creek, Yukon

Hi Bethany,

I am preparing a Well Head Protection Plan for a water well site located approximately 300 m southwest of Lot 1009, Deep Creek, YT; Block number Quad 105E/03; Plan number 69329 CLSR YT 72673 LTO YT.

The UTM coordinates for the site is approximately 6 770 798 N and 488 393 E in Zone 8N. The NTS map sheet is 105E/03.

- *It would be preferable to include any spills/contaminated sites within a radius of 10km for the purposes of this project.*

I would appreciate a review of the contaminated sites and spill records to determine if there have been any documented spills on the property or the nearby properties (<10km radius). Thank you for your assistance. If you require any further information, please feel free to contact me.

Please note that your response will be included with the final report, for record keeping.

Thank you,

Rob

**Rob Dickson, EIT** | Environmental Engineer | Water Resources Discipline | EBA Environment Practice  
Direct +1 (867) 668-9243 | [Rob.Dickson@tetrattech.com](mailto:Rob.Dickson@tetrattech.com)

**Tetra Tech** | Complex World, Clear Solutions™  
EBA Environment Practice | 61 Wasson Place, Whitehorse, YT, Canada Y1A 0H7 | [tetrattech.com](http://tetrattech.com)

 please consider the environment before printing this email